

231E

NFPA 231E

Recommended
Practice for the
Storage of
Baled Cotton
1996 Edition



National Fire Protection Association, 1 Batterymarch Park, PO Box 9101, Quincy, MA 02269-9101
An International Standards-Making Organization

NOTICE

All questions or other communications relating to this document should be sent only to NFPA headquarters, addressed to the attention of the Committee responsible for the document.

For information on the procedures for requesting Technical Committees to issue Formal Interpretations, proposing Tentative Interim Amendments, proposing amendments for Committee consideration, and appeals on matters relating to the content of the document, write to the Secretary, Standards Council, National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

A statement, written or oral, that is not processed in accordance with Section 16 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Users of this document should consult applicable federal, state and local laws and regulations. NFPA does not, by the publication of this document, intend to urge action that is not in compliance with applicable laws, and this document may not be construed as doing so.

Policy Adopted by NFPA Board of Directors on December 3, 1982

The Board of Directors reaffirms that the National Fire Protection Association recognizes that the toxicity of the products of combustion is an important factor in the loss of life from fire. NFPA has dealt with that subject in its technical committee documents for many years.

There is a concern that the growing use of synthetic materials may produce more or additional toxic products of combustion in a fire environment. The Board has, therefore, asked all NFPA technical committees to review the documents for which they are responsible to be sure that the documents respond to this current concern. To assist the committees in meeting this request, the Board has appointed an advisory committee to provide specific guidance to the technical committees on questions relating to assessing the hazards of the products of combustion.

Licensing Provision

This document is copyrighted by the National Fire Protection Association (NFPA). The terms and conditions set forth below do not extend to the index to this document. If public authorities and others reference this document in laws, ordinances, regulations, and administrative orders or similar instruments, it should be with the understanding that this document is informative in nature and does not contain mandatory requirements. Any deletions, additions, and changes desired by the adopting authority must be noted separately. Those using this method ("adoption by reference") are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use.

The term "adoption by reference" means the citing of the title and publishing information only.

(For further explanation, see the Policy Concerning the Adoption, Printing, and Publication of NFPA Documents, which is available upon request from the NFPA.)

Statement on NFPA Procedures

This material has been developed under the published procedures of the National Fire Protection Association, which are designed to assure the appointment of technically competent Committees having balanced representation. While these procedures assure the highest degree of care, neither the National Fire Protection Association, its members, nor those participating in its activities accept any liability resulting from compliance or noncompliance with the provisions given herein, for any restrictions imposed on materials or processes, or for the completeness of the text.

NFPA has no power or authority to police or enforce compliance with the contents of this document, and any certification of products stating compliance with requirements of this document is made at the peril of the certifier.

Copyright © 1996 NFPA, All Rights Reserved

NFPA 231E

Recommended Practice for the

Storage of Baled Cotton

1996 Edition

This edition of NFPA 231E, *Recommended Practice for the Storage of Baled Cotton*, was prepared by the Technical Committee on General Storage and acted on by the National Fire Protection Association, Inc., at its Fall Meeting held November 13-15, 1995, in Chicago, IL. It was issued by the Standards Council on January 12, 1996, with an effective date of February 2, 1996, and supersedes all previous editions.

Changes other than editorial are indicated by a vertical rule in the margin of the pages on which they appear. These lines are included as an aid to the user in identifying changes from the previous edition.

This edition of NFPA 231E was approved as an American National Standard on February 2, 1996.

Origin and Development of NFPA 231E

In the early 1900s, a group of marine underwriters formulated regulations to reduce the frequency of excessive fire loss in baled cotton facilities. In 1916, following a joint conference with the cotton industry, guidelines were established under the title "Specifications and Standards" (also known as "Marine Standards").

From 1947 through 1969, the sponsorship was through the Cotton Warehouse and Inspection Service (dissolved in 1969). In 1967, interested insurance rating bureaus were added as sponsors, and, in 1969, to prevent conflicts with various rating bureau schedules, the word "Standards" was replaced with "Recommended Good Practices"; however, since 1939, the booklet has been commonly referred to as the "Blue Book."

Numerous revisions have been made over the years to keep current, the last made in 1973. Early in 1978, the committee for the "Blue Book" requested that the NFPA consider a standard on baled cotton storage and handling based on the "Blue Book" recommended practices. The NFPA Correlating Committee for Storage expanded the scope to include all fibers in baled form, which were covered in NFPA 44, *Storage of Combustible Fibers*, which was withdrawn many years ago.

Little data was found on fire experience for baled fibers, other than cotton, and that data was largely empirical in nature.

Therefore, NFPA 231E was developed by consensus of a test group formed in 1978 and made up of the cotton warehousing, cotton processing, and insurance industries, under the auspices of the Technical Committee on General Storage, and is limited to cotton fiber in baled form, with the intent to convert to a standard as field experience becomes available to further substantiate its content.

The 1989 edition was a reconfirmation of the 1984 edition.

The 1996 edition incorporates a number of editorial changes to improve the user friendliness of the document. In addition, the terminology has been updated to reflect current practices.

Technical Committee on General Storage

William P. Thomas, Chair
Kemper Nat'l Insurance Cos., IL

Christopher T. Lummus, Secretary
ISO Commercial Risk Services, Inc., TX

Hamid R. Bahadori, City of Orlando Fire Dept., FL
J. S. Barritt, Eastham, MA
Rep. Industrial Risk Insurers
Robert B. Combs, Johnson & Higgins of Washington Inc., WA
Thomas P. Conlon, M&M Protection Consultants, NJ
Reeder W. (Wick) Dossett, Central Texas Warehouse Corp., TX
Rep. Cotton Warehouse Assn. of America
Robert C. Everson, Calabash, NC
James G. Gallup, Rolf Jensen & Assoc., Inc., IL
James Golinveaux, Central Sprinkler Corp., PA
Rep. Nat'l Fire Sprinkler Assn.
Thomas Goonan, Tom Goonan Assoc., VA
Richard S. Johnson, Hilton Head, SC
Rep. Owens-Illinois
Michael T. Kroman, Fireman's Fund Insurance Co., CA
Rodney A. McPhee, Canadian Wood Council, ON, Canada

John F. Murphy, Dow Chemical U.S.A., TX
Rep. Chemical Mfrs. Assn.
Jennifer L. Nelson, AT&T Co., NJ
Gerald W. O'Rourke, O'Rourke & Co., CA
Philip E. SanFilippo, Headquarters, Military Traffic Mgmt. Command, Bayonne, NJ
Jerry Shiner, Keepsafe Systems, Inc., ON, Canada
Peter A. Smith, Int'l Paper Co., TN
Robert D. Spaulding, Factory Mutual Research Corp., MA
Jack Thacker, Allan Automatic Sprinkler Corp. of Southern California
Rep. Nat'l Fire Sprinkler Assn.
Peter Thomas, The Viking Corp., MI
Rep. American Fire Sprinkler Assn.
F. A. Underwood, The Trinity Co., TX
Terry L. Victor, Automatic Sprinkler Corp. of America, MD
Charles Walker, IRM Insurance, NC

Alternates

John Davis, State Bonded Warehouse & Storage, AL
(Alt. to R. W. Dossett)
Salvatore Gitto, M&M Protection Consultants, NY
(Alt. to T. P. Conlon)
Joseph B. Hankins, Jr., Factory Mutual Research Corp., MA
(Alt. to R. D. Spaulding)
Stephen R. Hoover, Kemper Nat'l Insurance Cos., IL
(Alt. to W. P. Thomas)

Richard E. Hughey, ISO Commercial Risk Services, Inc., NJ
(Alt. to C. T. Lummus)
James M. Ingalls, Industrial Risk Insurers, CT
(Alt. to J. S. Barritt)
Kenneth E. Isman, Nat'l Fire Sprinkler Assn., NY
(Alt. to J. Thacker)
William A. Webb, Rolf Jensen & Assoc., Inc., IL
(Alt. to J. G. Gallup)

Nonvoting

Martin M. Brown, Laguna Hills, CA
(Member Emeritus)

Sultan M. Javeri, AXA - UniEurope

Milosh T. Puchovsky, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the text of this edition. Since that time, changes in the membership may have occurred.

NOTE: Membership on a Committee shall not in and of itself constitute an endorsement of the Association or any document developed by the Committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on safeguarding general warehousing and commodities stored indoors or outdoors against fire. This Committee does not cover storage specifically covered by other NFPA standards.

Contents

Chapter 1 Introduction	231E- 4	5-2 Definitions	231E- 8
1-1 Scope	231E- 4	5-3 Site	231E- 8
1-2 General	231E- 4	5-4 Storage Arrangements	231E- 8
1-3 Definitions	231E- 4	5-5 Quarantine Yards	231E- 9
Chapter 2 Building Construction	231E- 5	5-6 Unobstructed Clear Space	231E- 9
2-1 Construction	231E- 5	5-7 Fire Protection	231E- 9
2-2 Emergency Smoke and Heat Venting	231E- 5	5-8 Yard Maintenance and Operations . . .	231E- 9
2-3 Fire Divisions or Clear Spaces between Buildings	231E- 5	Chapter 6 Administration, Buildings, Equipment, Maintenance, and Operations	231E-10
Chapter 3 Storage Arrangements	231E- 5	6-1 Administration	231E-10
3-1 General	231E- 5	6-2 Mechanical Handling Equipment	231E-10
3-2 Storage Blocks	231E- 5	6-3 Building Service and Equipment	231E-10
3-3 Aisles	231E- 6	6-4 Cutting and Welding	231E-11
3-4 Freshly Ginned Cotton Bales	231E- 6	6-5 Waste Disposal	231E-11
3-5 Storage of Commodities Other than Cotton	231E- 6	6-6 Smoking	231E-11
3-6 Clearances	231E- 6	6-7 Maintenance and Inspection	231E-11
Chapter 4 Fire Protection	231E- 6	6-8 Grass and Weeds	231E-11
4-1 Automatic Sprinkler Systems	231E- 6	Chapter 7 Referenced Publications	231E-11
4-2 Water Supplies	231E- 7	Appendix A Explanatory Material	231E-12
4-3 Hydrants	231E- 7	Appendix B Guidelines for Fighting Fires in Baled Cotton	231E-14
4-4 Manual Inside Protection	231E- 7	Appendix C Referenced Publications	231E-16
4-5 Alarm Service	231E- 8	Index	231E-16
4-6 Fire Emergency Planning	231E- 8		
Chapter 5 Yard Storage	231E- 8		
5-1 General	231E- 8		

NFPA 231E**Recommended Practice for the
Storage of Baled Cotton****1996 Edition**

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates explanatory material on that paragraph in Appendix A.

Information on referenced publications can be found in Chapter 7 and Appendix C.

Chapter 1 Introduction**1-1 Scope.**

1-1.1 This recommended practice provides fire protection guidance for the storage of baled cotton in buildings and in yards.

1-1.2 None of the provisions outlined should be considered mandatory; however, it is recommended that property owners follow these recommended practices as a minimum means of limiting firespread by the application of the storage methods specified, by the separation of major storages using fire walls or clear spaces, and by the provision of an adequate means of extinguishment.

1-1.3 These guidelines may be permitted to be applied to new or existing facilities.

1-1.4 There is no intent to restrict new technologies or alternative arrangements that offer protection features superior to those outlined.

1-2 General.

1-2.1 Cotton fiber is readily ignitable and burns freely and, when stored in relatively large quantities, poses special fire control problems not generally encountered in other common commodities.

Cotton fiber is compressed to various densities into baled form for transport, storage, and handling and is largely covered by industry-accepted packaging materials and bound by steel, synthetic or wire bands, or wire. The bale surfaces normally are ragged in appearance due to the loose fibrous material not confined by the binding or wrapping. Frequently, this ragged appearance is further aggravated by sampling, which exposes additional fibrous material and can contribute to the rapid spread of fire.

Bale storage in relatively large quantities can pose severe fire control problems due to the potential flashover and the large area of involvement that could overcome even a well designed and supplied sprinkler system; therefore, this recommended practice takes into consideration limits on the number of bales per building or fire division and the size of storage blocks.

Where the bales are tiered or piled in buildings or outdoors, the loose surface fibers are easily ignited in the presence of an ignition source and the fire can spread rapidly over the entire mass or body of the material; this commonly is called "flashover." Fire then can burrow into the bale interiors making detection and extinguishment diffi-

cult, particularly in large mass storage. A quick, hot fire then can ensue and spread beyond the control of ordinary extinguishing methods.

In properly arranged storage and with adequate automatic sprinkler protection, fire normally is confined to the pile of origin, although an aisle fire can be expected to involve more than one tier or pile. Sprinklers usually operate beyond the confines of the fire and wet down bales immediately adjacent to the burning pile.

If adequate sprinkler protection is lacking, if tiers or piles are too large or high, if aisle separation is not properly maintained, or if the bales are otherwise improperly arranged, damage to the section, building, or area of involvement will be more severe, if not totally destructive.

1-2.2 Common causes of fire in baled cotton include, but are not limited to:

- (a) Fire-packed bales from the ginning or other process.
- (b) Steel bands breaking and striking or rubbing (friction) against each other or other metallic objects causing sparks.
- (c) Extraneous sparks from sources such as vehicle exhausts and incinerators.
- (d) Miscellaneous sources such as cutting and welding, electrical and mechanical faults, and smoking.

1-3 Definitions. Unless expressly stated elsewhere, for the purpose of this document, the following definitions apply:

Approved.* Acceptable to the authority having jurisdiction.

Authority Having Jurisdiction.* The organization, office, or individual responsible for approving equipment, an installation, or a procedure.

Baled Cotton.* A natural seed fiber wrapped and secured in industry-accepted materials, usually consisting of burlap, woven polypropylene or sheet polyethylene, and secured with steel, synthetic or wire bands, or wire; can also include linters (lint removed from the cottonseed) and motes (residual materials from the ginning process). (See Table A-1-3.)

Block Storage. The number of bales closely stacked in cubical form and enclosed by aisles or building sides, or both.

Cold Cotton. Baled cotton five or more days old after the ginning process.

Fire-packed. A bale within which a fire has been packed as a result of a process, with ginning being the most frequent cause.

Flameover. A fire that spreads rapidly over the exposed linty surface of the bales. In the cotton industry, the common term is "flashover" and has the same meaning.

Flashover. See Flameover.

Labeled. Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation that maintains periodic inspection of production of labeled equipment or materials and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

Listed.* Equipment or materials included in a list published by an organization acceptable to the authority having jurisdiction and concerned with product evaluation that maintains periodic inspection of production of listed equipment or materials and whose listing states either that the equipment or material meets appropriate standards or has been tested and found suitable for use in a specified manner.

Naked Bale. A bale secured with wire or steel straps without wrapping.

Racks. Any combination of vertical, horizontal, and diagonal members that supports stored materials. Some rack structures use solid shelves. Racks can be fixed or portable.

Should. Indicates a recommendation or that which is advised but not required.

Tiered Storage. An arrangement in which bales are stored directly on the floor or ground, usually on dunnage where stored outdoors, and two or more bales high.

Yard Storage. An arrangement in which bales are stored outdoors in any open area. See Section 5-2 for additional definitions that apply to yard storage only.

Chapter 2 Building Construction

2-1 Construction.

2-1.1 Buildings used for the storage of baled cotton that is stored and protected in accordance with this recommended practice may be permitted to be of any of the types described in NFPA 220, *Standard on Types of Building Construction*.

2-1.2 Buildings that are equipped, or that are to be equipped, with automatic sprinkler protection also should meet the recommendations of Chapter 4.

2-2 Emergency Smoke and Heat Venting. The protection outlined in this recommended practice applies to buildings with or without roof vents and draft curtains.

2-3 Fire Divisions or Clear Spaces between Buildings.

2-3.1 A fire division is a building, compartment, or section cut off by fire walls or separation.

2-3.1.1 Fire divisions or clear spaces between buildings should be in accordance with NFPA 80A, *Recommended Practice for Protection of Buildings from Exterior Fire Exposures*.

2-3.1.2 Baled cotton storage generally has a fire load in excess of 15 lb/ft² (73 kg/m²), which would place its classification, according to NFPA 80A, *Recommended Practice for Protection of Buildings from Exterior Fire Exposures*, in the "severe" category.

2-3.2* Fire walls should be of masonry and rated for at least 4 hours (based on NFPA 251, *Standard Methods of Tests of Fire Endurance of Building Construction and Materials*; ASTM E 119, *Standard Methods for Fire Tests of Building Construction and Materials*; and UL 263, *Standard for Safety Fire Tests of Fire Resistance of Building Construction and Materials*). Such walls should be parapeted as follows:

(a) For wood frame [Type V (111-000)] and ordinary or heavy timber masonry [Type III (211-200) and Type IV

(2 HH)], construction parapets should extend at least 5 ft (1.5 m) above the highest point of any adjacent monitor or roof structure within 50 ft (15.2 m) of the fire wall. Where the monitors or the roof structure adjoins a fire wall, the parapet should extend not less than 7½ ft (2.3 m) horizontally from the vertical side of the roof structure. If intersecting end or side walls are other than masonry, the fire wall should extend outward 10 ft (3.1 m) beyond the end or side wall or should be "teed" at the ends 10 ft (3.1 m) from each side of the wall or should be "elled" 20 ft (6.1 m) and of an equivalent fire rating.

(b) For noncombustible construction [Type II (000)] other than that outlined in 2-3.2(c), parapets should be at least 2½ ft (0.75 m) above the roof. If intersecting side walls are other than masonry, such wall construction should conform to the specifications of 2-3.2(a).

(c) For noncombustible construction [Type II (222-111)] having masonry walls and with roofs of concrete, gypsum, or Class 1 (UL classified) metal deck, the parapet should extend at least 12 in. (0.3 m) above the roof.

(d) For walls and roofs of fire-resistive construction, [Type I (443-332)] parapets are not necessary.

2-3.3 Fire walls should be free of openings. Where openings are necessary, the number should be kept to the minimum necessary, and each side should be protected by an approved and listed 3-hour-rated fire door, installed in accordance with NFPA 80, *Standard for Fire Doors and Fire Windows*. Doors should be automatic closing with detectors or fusible links installed on both sides of the opening and interconnected so that the operation of any single detector or fusible link closes both doors simultaneously.

2-3.4 Substantial guards of a size to protect fire doors from damage or obstruction should be provided.

Chapter 3 Storage Arrangements

3-1 General.* This chapter applies to buildings protected by a sprinkler system in accordance with Chapter 4, or to those not so protected. The tier heights, block sizes, and aisle widths outlined may be permitted but represent recommended maximum and minimum limitations. Fire experience and fire tests of high-piled commodities have shown that lower pile heights, smaller block sizes, and wider aisles result in a substantial delay in firespread and in providing for manual fire fighting. Automatic sprinkler effectiveness is also improved substantially, with a reduction in water demand and a decrease in the quantity of goods damaged.

3-2 Storage Blocks.

3-2.1 Storage blocks, tiered or untiered, or on racks, should be limited to 700 bales of compressed cotton or 350 bales of flat cotton. (See 3-3.4 for a permitted variation and also Table A-1-3 for typical cotton bale types and approximate sizes.)

3-2.2 The height of tiered or rack storage should be limited to a nominal 15 ft (4.6 m). Rack storage, as used in this document, contemplates baled cotton in a skeleton steel pipe or tubular frame, without shelving, and is limited to a single- or double-row configuration not in excess of two bales deep. Any variation could create a serious handicap to automatic sprinklers that is beyond the design capability and should be referred to the authority having jurisdiction.

3-2.3 Rack storage should not extend over aisles or doorways.

3-2.4 Racks should not be loaded beyond their design capacity and should be designed for seismic conditions in areas where seismic resistance for buildings is required.

3-3 Aisles.

3-3.1 Aisles should be provided and maintained to minimize the spread of fire and to allow convenient access for fire fighting, removal of storage, and salvage operations.

3-3.2 At least one main aisle, 12 ft (3.7 m) or more in width, should be provided in each fire division and arranged to subdivide the storage into two or more approximately equal areas.

3-3.3 Cross aisles separating each storage block should be at least 4 ft (1.2 m) in width. The recommended 4-ft (1.2-m) aisles allow sprinkler water to penetrate the lower areas of storage; however, it should be noted that, for aisles less than 8 ft (2.4 m) in width, a fire can be expected to communicate readily from one block to another, especially in the case of an easily ignitable commodity such as cotton fiber.

3-3.4 Where a 15-ft (4.6-m) cross aisle is provided after every fourth or fifth tiered block, each storage block may be permitted to be increased to 800 bales of compressed cotton and 400 bales of flat cotton. The purpose of this alternate method of tiered storage is to encourage wider cross aisles at least intermittently, without reducing the recommended storage capacity, as an aid in reducing the flashover fire potential. Because of the increase in block sizes, however, it is recommended that the authority having jurisdiction be consulted prior to practicing this method.

3-3.5 Cross aisles separating each single- or double-row rack storage configuration should be at least 10 ft (3.1 m) in width.

3-3.6 Aisles should be maintained free of loose cotton fibers.

3-4 Freshly Ginned Cotton Bales. See Section 5-5.

3-5 Storage of Commodities Other than Cotton.

3-5.1 Cotton warehouses, in general, may be permitted to be used for the storage of other commodities, subject to the following:

(a) The storage of other commodities in a building may be permitted where baled cotton is not stored.

(b) High hazard commodities, such as nitrates or similar oxidizing materials, flammable liquids or gases, explosives, or materials of a highly combustible nature, should not be permitted where baled cotton is stored in the fire division.

(c) Any commodities that could be hazardous in combination with each other should be stored so that they cannot come in contact with each other.

3-5.2 Where it is necessary to store other commodities with baled cotton storage, a clear space of at least 15 ft (4.6 m) should be maintained between the baled cotton storage and other commodities.

3-5.3 Where commodities of different classifications are permitted and stored in the same building, whether on a seasonal or other basis, the protection should be adequate

for the most hazardous material. (For protection of other commodities, see the applicable NFPA storage standards.)

3-6 Clearances.

3-6.1 Proper clearances from lights or light fixtures should be maintained to prevent possible ignition. Incandescent light fixtures should have guards to prevent ignition of a commodity from hot bulbs where the possibility of contact exists.

3-6.2 No storage should be located within 3 ft (0.9 m) of any electrical switch or panel boards and fuse boxes.

3-6.3 Baled cotton storage and other combustibles should be kept at least 4 ft (1.2 m) from fire door openings so that the transmission of fire through a door opening is minimized.

3-6.4 At least 2 ft (0.6 m) of clearance should be maintained around all doors (other than as indicated in 3-6.3), fire protection equipment (including automatic sprinkler risers, controlling valves, hose stations, and portable extinguishers), and telephones for accessibility.

3-6.5 A clearance of at least 3 ft (0.9 m) should be maintained between the top of storage and the roof or ceiling construction in order to allow sufficient space for the effective use of hose streams in buildings not equipped with automatic sprinkler protection.

Chapter 4 Fire Protection

4-1 Automatic Sprinkler Systems.

4-1.1 Automatic sprinkler protection is not part of the recommendations of this document. However, it is unfortunate that, in a fire situation, human response is, in most cases, unreliable in the first critical moments of fire development. Sprinkler protection is, therefore, the most reliable method of fire detection and suppression. Property owners are encouraged to provide sprinkler protection as the best means of minimizing a large loss. (See Section 3-5 for sprinkler protection for other than cotton fiber storage.)

4-1.2 Automatic sprinkler systems, where provided, should be installed in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

Exception: Where modified by this chapter.

4-1.3 For tiered or rack storage up to a nominal 15 ft (4.6 m) in height, sprinkler discharge densities and areas of application should be in accordance with Figure 4-1.3. The density provided for the area of operation can be taken from any point on the selected curve. It is not necessary to meet more than one point on the selected curve.

4-1.3.1 Where roof or ceiling heights would prohibit storage above a nominal 10 ft (3.1 m), the sprinkler discharge density may be permitted to be reduced by 20 percent of that indicated in Figure 4-1.3 but should not be reduced to less than 0.15 gpm/ft² [(0.10 L/sec)/m²].

4-1.3.2 Baled storage that is not tiered can be based on the single-point design curve E for wet-pipe systems and curve F for dry-pipe systems. This untiered design density limits storage to the height of one bale, on side or on end, and would likely prohibit any future tiering without redesign of the sprinkler system.




Figure 4-1.3 Sprinkler system design curves.

4-1.3.3 In warehouses that have mixed rack storage, tiered or untiered storage, or a combination of these, the curve applicable to the storage configuration should apply and the highest density recommendation should extend at least 15 ft (4.6 m) beyond the recommended operating area.

4-1.3.4 Minimum sprinkler operating areas should be 3000 ft² (279 m²) for wet-pipe systems and 3900 ft² (363 m²) for dry-pipe systems; the maximum operating area should not exceed 6000 ft² (557 m²). No area credit is recommended for the use of high temperature sprinklers.

4-1.3.5* On new installations, the use of sprinkler heads in the ordinary temperature range is recommended, subject to the maximum ceiling temperatures outlined in NFPA 13, *Standard for the Installation of Sprinkler Systems*.

4-1.4 Clearance between the top of the storage and the sprinkler deflectors should be at least 18 in. (0.45 m). Building heights should allow for proper clearance between the pile height and sprinkler deflectors. Fire tests of high-piled storage have shown that sprinklers are generally more effective if located 1½ ft to 4½ ft (0.45 m to 1.4 m) above the storage height.

4-2 Water Supplies.

4-2.1 The total water supply available should be sufficient to provide the recommended sprinkler discharge density over the area to be protected, plus a minimum of 500 gpm (32 L/sec) for hose streams.

4-2.2 Water supplies should be capable of supplying the total demand for sprinklers and hose streams for not less than 2 hours.

4-2.3 Recommended water supplies contemplate successful sprinkler operation when installed. However, because of the flashover fire potential and inherent unfavorable features of cotton warehousing, there should be an adequate water supply available for fire department use.

4-3 Hydrants. At locations without public hydrants, private hydrants should be provided in accordance with NFPA 24, *Standard for the Installation of Private Fire Service Mains and Their Appurtenances*.

4-4 Manual Inside Protection.

4-4.1 In buildings of 15,000 ft² (1380 m²) or larger, small hose [1½ in. (38.1 mm)], with combination water spray nozzle, should be provided to reach any portion of a storage area with due consideration to access aisle configuration with a maximum length of 100 ft (30.5 m) of hose. Such small hose should be supplied from one of the following:

- Outside hydrants;
- A separate piping system for small hose stations in accordance with NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*;
- Valved hose connections on sprinkler risers where such connections are made upstream of the sprinkler control valves;
- Adjacent sprinkler systems in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

4-4.2 Portable listed fire extinguishers should be provided in accordance with NFPA 10, *Standard for Portable Fire Extinguishers*, and as amended by this chapter. Up to ½ of the required complement of portable fire extinguishers for Class A fires may be permitted to be omitted in storage areas where fixed small hose lines are installed in accordance with 4-4.1.

4-4.2.1 Cotton and its wrappings represent a Class A fire. Experience has shown that extinguishment using "wet water" (a chemical agent additive to lower the surface tension of water, thus increasing its penetrating and spreading qualities) is the most effective on baled cotton fires.

Plain water is effective on surface fires but lacks the penetrating power of wet water.

Dry chemical extinguishers using sodium bicarbonate, potassium bicarbonate, or potassium chloride base powders have been used to control a surface fire on baled fibers and work mainly by coating the fiber with the fire retardant powder, but such chemicals do not affect a smoldering or burrowing fire beneath the surface.

4-4.2.2 Additional listed extinguishers, suitable for Class B and C fires, or multipurpose types, should be provided at each press location and for each motorized vehicle or area of hazard other than Class A.

4-4.3 Wetting Agent Extinguishing Units.

4-4.3.1 Pressurized, wheeled, listed, wetting agent extinguishing units, as specified in NFPA 18, *Standard on Wetting Agents*, may be permitted to be used, subject to the authority having jurisdiction, in lieu of Class A conventional types or small hose lines, provided:

(a) The unit(s) has an equivalent extinguishing effectiveness of 20A for each 15,000 ft² (1380 m²) of floor area or less.

(b) The unit(s) has an equivalent extinguishing effectiveness of 40A or more for each 30,000 ft² (2760 m²) of floor area.

4-4.3.2 Placement of extinguishing units should be at locations readily accessible to the main aisles and properly protected from damage.

4-4.4 Extinguishers should be of the nonfreezing type or protected against freezing where necessary.

4-5 Alarm Service.

4-5.1 Automatic sprinkler systems should have approved central station, local, auxiliary, remote station, or proprietary waterflow supervised alarm service. Local waterflow alarm service may be permitted where standard guard service is provided in accordance with NFPA 601, *Standard for Security Services in Fire Loss Prevention*.

Alarm service should comply with NFPA 72, *National Fire Alarm Code*.

4-5.2 Valves should be supervised in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

4-6 Fire Emergency Planning.

4-6.1 Arrangements should be made to allow rapid entry into the premises by the municipal fire department, police department, or other authorized personnel in the case of fire or other emergency.

4-6.2 Industrial fire brigades, where provided, should be in compliance with NFPA 600, *Standard on Industrial Fire Brigades*.

4-6.3 Manual fire-fighting operations should not be considered to be a substitute for sprinkler operation. The sprinkler system should be kept in operation during manual fire-fighting operations until visibility has improved so that the fire can be clearly seen and the extent of fire has been reduced to a mop-up stage. It is essential that charged hose lines be available before venting is started because of a possible increase in fire intensity. When a sprinkler valve is closed, a designated person should remain at the valve so it can be opened promptly if necessary. The water supply for the sprinkler system should be augmented, where possible, and care should be exercised so that the water supply for the sprinkler system is not rendered ineffective by the use of excessive hose streams.

4-6.4* Fire departments should be encouraged to make periodic inspections of the property in cooperation with management and personnel for the purposes of loss prevention and prefire planning.

4-6.5 A fire watch should be maintained when the sprinkler protection is not in service.

Chapter 5 Yard Storage

5-1 General.

5-1.1 This chapter applies to baled cotton storage yards designated for that purpose. Generally, yards are at or convenient to compression warehouses and gins but can include storage at locations remote from routine operations.

5-1.2 This chapter refers to seed cotton trailers or modules, vehicles, incinerators, and other facilities, or exposures from same, only for the purpose of establishing recommended distances to designated yard storage areas.

5-2 Definitions. Unless expressly stated elsewhere, the following definitions are for the purpose of this chapter only:

Block. A basic yard storage unit comprising multiple row storage with clear spaces on all sides.

Designated Yard. An area marked by boundary lines intended for outside storage purposes only.

Group of Yards. Multiple yards with a maximum block and minimum clear space limitations.

Protected. See Section 5-7.

Quarantine Yard. A segregated area for the storage of known or suspect fire-packed bales.

Row. A minimum yard storage unit comprised of adjoining bales.

Unprotected. Not meeting the provisions of Section 5-7.

Yard. A storage unit consisting of multiple storage blocks subject to bale and clear space limitations.

5-3 Site. Preference should be given to locations having adequate public fire and police protection, adequately supplied fire hydrants for protection of yard areas, good drainage, all-weather roads or driveways for emergency vehicle use, and remoteness from buildings or other combustible storages or facilities that could constitute an exposure hazard.

5-4 Storage Arrangements.

5-4.1 Tiered storage is not recommended; however, yard or outdoor storage conditions can necessitate storage methods other than those outlined. The authority having jurisdiction should be consulted for approval in such cases.

5-4.2 Storage should be arranged to provide reasonable fire breaks and ready access for fire fighting.

5-4.3 A row of storage should be limited to 100 bales.

5-4.4 Maximum storage limitations should be as follows:

- (a) Protected block, 10 rows (1000 bales);
- (b) Unprotected block, five rows (500 bales);
- (c) Protected yard, five protected blocks (5000 bales);
- (d) Unprotected yard, five unprotected blocks (2500 bales);
- (e) Protected group yard, four protected yards (20,000 bales);
- (f) Unprotected group yard, four unprotected yards (10,000 bales).

5-4.5 Minimum clear spaces should be as follows:

- (a) 10 ft (3.1 m) between parallel rows and 25 ft (7.6 m) between rows arranged end-to-end;
- (b) 50 ft (15.2 m) between protected or unprotected blocks;
- (c) 200 ft (61 m) between protected or unprotected yards;
- (d) 1000 ft (305 m) between protected or unprotected group yards.

5-4.6 Rows should be arranged so that prevailing winds blow in the direction of the parallel clear spaces between rows.

5-5 Quarantine Yards.

5-5.1 Freshly ginned cotton bales, commonly called “fire-packed bales,” are highly subject to insidious fires originating from the ginning operation. Known or suspect fire-packed bales should be marked as such and kept segregated from other contents or buildings for a period of not less than 5 days; if no fire is detected after that period, the bales then can be handled in a normal manner. (See *Appendix B*.)

5-5.2 A clear space of at least 100 ft (30.5 m) from any yard storage and 25 ft (7.6 m) from all buildings should be established as a quarantine area for known or suspect fire-packed bales.

5-5.3 Known or suspect fire-packed bales should be separated from each other by at least a 10-ft (3.1-m) clear space.

5-6* Unobstructed Clear Space. Unobstructed clear space to designated yard storage should be maintained as follows:

- (a) 100 ft (30.5 m) to any approved sprinklered building;
- (b) 200 ft (61 m) to any nonapproved sprinklered or nonsprinklered building;
- (c) 200 ft (61 m) to an approved incinerator;
- (d) 500 ft (152.5 m) to a nonapproved incinerator or open fires;
- (e) 100 ft (30.5 m) to vehicle and seed trailer or module parking areas and trash piles;
- (f) 50 ft (15.2 m) to roadways and railroad mainlines and sidings;
- (g) 200 ft (61 m) upwind of any reconditioning activity;
- (h) Yard storage areas should be maintained clear and clean of loose cotton, dry grass, weeds, and combustible trash for a distance of at least 50 ft (15.2 m) around the yard perimeter.

5-7 Fire Protection.

5-7.1 To qualify as a protected yard, hydrants should comply with Section 4-3.

Exception: Where amended by this chapter.

5-7.1.1 All areas of yard storage should be within 500 ft (152.5 m) of a fire hydrant. Adequate clearance should be maintained between storage and hydrants.

5-7.1.2* Hydrant equipment for each yard group (20,000 bales) should consist of:

- (a) 250 ft (76.2 m) of 2½-in. (63.5-mm) hose.
- (b) 300 ft (91.5 m) of 1½-in. (38.1-mm) hose with provisions to “Y-connect” to the 2½-in. (63.5-mm) hose.
- (c) Combination water spray nozzles.
- (d) Proper wrenches for hydrant operation and hose connections.

5-7.1.3 Water available to the most remote yard hydrants should be capable of delivering at least 500 gpm (1893 L/min) at an effective pressure for at least a 2-hour period.

5-7.2 Approved extinguishing units should be provided on the basis of an equivalent 40A rating for each protected or unprotected yard area (see *Section 5-4*) or greater fraction thereof.

5-7.2.1 Subject to the authority having jurisdiction, a motorized wet water unit(s) may be permitted to be substituted for that specified in 5-7.2, provided that a unit of 250 gal (946 L) or greater capacity is provided for each group yard area storing up to 20,000 bales.

5-7.2.2 Placement of wheeled or motorized units should be at readily accessible locations within 250 ft (76.2 m) of each yard, protected from damage, and maintained in good operating condition at all times.

5-7.3 Water containers and pails, if used, should be distributed at a ratio of one 40-gal (151-L) or greater container with two pails for each 100 bales of storage. However, wheeled wet water pressure extinguishers may be permitted in lieu of containers and pails.

5-7.4 All motorized vehicles used in designated yard areas should be equipped with a listed multipurpose dry chemical extinguisher of a size appropriate for the anticipated hazard. (See 4-4.2 for information on portable fire extinguishers.)

5-7.5 A suitable and reliable means of communication should be available to summon the fire department or other appropriate personnel promptly, to sound a general alarm in the case of fire or other emergency, or both.

5-7.6 Reference should be made to Section 4-6 for fire emergency planning and procedures that apply to yard storage.

5-8 Yard Maintenance and Operations.

5-8.1 Smoking should be strictly prohibited within 100 ft (30.5 m) of yard storage areas, and “no smoking” signs should be posted conspicuously. (See A-6-6.)

5-8.2* All internal combustion equipment used in or around yard storage areas should be equipped with a suitable spark arrester-type muffler properly maintained and otherwise approved by the authority having jurisdiction.

5-8.3 Guard Watch Service.

5-8.3.1 Guard watch service should be provided throughout all designated yard storage areas during all shutdown periods when fewer than 5 days have passed after cotton bales have been ginned, or when the total stock exceeds 1000 bales.

5-8.3.2 Hourly rounds should be made and recorded during all nonworking hours using an approved and listed portable clock and having key stations situated to ensure complete coverage of the area of responsibility. Watch service information should be obtained from NFPA 601, *Standard for Security Services in Fire Loss Prevention*.

Chapter 6 Administration, Buildings, Equipment, Maintenance, and Operations

6-1 Administration. The administration of buildings and equipment, and the maintenance thereof, is an important consideration in the reduction of fire incidence and loss. The finest buildings and protective features can be abrogated quickly by neglect of the continuous, necessary maintenance of fire loss prevention programs and protective equipment. Thus, management, at all levels, plays a critical part in the reduction of fire loss.

In addition to the recommendations outlined in this chapter, the liaison between management and personnel should include a meaningful loss prevention program that:

- (a) Encourages loss prevention habits;
- (b) Teaches the prompt sounding of alarms;
- (c) Minimizes panic and effects safe evacuation;
- (d) Instructs key personnel in the effective utilization of fire extinguishing equipment and other protective features; and
- (e) Teaches basic salvage and cleanup techniques to minimize the downtime of operations.

6-2 Mechanical Handling Equipment.

6-2.1 Industrial Trucks. Power operated industrial trucks and mobile equipment should comply with NFPA 505, *Fire Safety Standard for Powered Industrial Trucks Including Type Designations, Areas of Use, Maintenance, and Operation*. Cotton storage and handling areas are defined as Class III, Division 2, hazardous areas and require vehicles designated as types DS, DY, ES, EE, EX, GS, LPS, and GS/LPS.

6-2.1.1 Gasoline and diesel fuel should be prohibited in cotton storage areas, on platforms, and in exposing yard areas. Fueling should be done outside at a well-detached location in accordance with NFPA 30, *Flammable and Combustible Liquids Code*.

Exception: Gasoline and diesel fuel contained in the vehicle tanks may be permitted.

6-2.1.2 Liquefied petroleum gas fuel containers shall be exchanged or removed only outdoors. The valve at the fuel container should be closed and the engine allowed to run until the fuel line is exhausted. Tanks should be refueled only at well-detached locations. LP-Gas fuel systems on LP-Gas dual fuel powered trucks should be in accordance with the applicable provisions of NFPA 58, *Standard for the Storage and Handling of Liquefied Petroleum Gases*.

6-2.1.3 Charging equipment for storage batteries should be in a separate area, room, or building designated for that purpose. If located in a separate room, the room should be lined with substantial noncombustible materials constructed to exclude "fly" or lint. Charging areas should be

kept free of extraneous combustible materials and trash. Adequate ventilation should be provided to minimize concentrations of hydrogen gas during charging.

6-2.1.4 All mechanical equipment and refueling areas should be kept free of accumulations of fibrous lint, oil, and trash, with particular attention paid to the internal areas of vehicles.

6-2.2* Maintenance and Operations. The following recommendations should be met prior to the entrance or use of industrial trucks in a cotton storage or handling area:

- (a) All traces of fuel should be cleaned from the vehicle before it is started.
- (b) Vehicles that have exhausted fuel tanks should be towed to the assigned fueling area for refueling.
- (c) Repairs should be prohibited in cotton storage or handling areas.
- (d) Alterations of the fire safety features should be prohibited.
- (e) Maintenance procedures should comply with those outlined in NFPA 505, *Fire Safety Standard for Powered Industrial Trucks Including Type Designations, Areas of Use, Maintenance, and Operation*. (See 6-2.1.)

6-2.3 Interplant Haulage. Tractors used for interplant hauling should be equipped with a properly maintained, suitable, spark arrester-type muffler.

6-2.4 Motorized Vehicles. Motorized vehicles, other than those specified under 6-2.1, should not be permitted to enter any cotton storage area. A loading platform should be located so that trucks cannot fully enter inside the closing walls of a warehouse, with the truck space inclined away from the platform and lower than the platform. The loading area should be closed off from any under-floor building space.

6-2.5 Mechanical handling equipment, when not in use, should be stored outside.

6-3 Building Service and Equipment.

6-3.1 Electrical Installation.

(a) It is recommended that cotton storage and handling areas be free of electrical installations; however, installations that are necessary should comply with NFPA 70, *National Electrical Code®*, for Class III, Division 2, hazardous areas.

(b) Electrical extension cords should be prohibited in storage areas. If portable lights are necessary, battery-powered lanterns or flashlights may be permitted to be used.

6-3.2 Open flame heating devices, permanent or temporary, should be prohibited.

6-3.3 Shops and Equipment.

6-3.3.1 Repairing and reconditioning and boilers or similar equipment should be prohibited in cotton storage areas. Separate buildings should be provided for such purposes or should be separated from storage areas by a standard 2-hour fire wall.

6-3.3.2 The term "reconditioning" applies mainly to cotton and is defined as any opening, drying, cleaning, or picking of bales of loose cotton by any means whatsoever.

Exception No. 1: Air drying (not compressed air) of baled cotton at room temperature where not more than one band is removed from each bale being so dried.

Exception No. 2: The picking of baled cotton by hand where not more than five bales are in the process of being picked on the premises at any one time, and where at least two bands remain on each bale so picked. Removal of more than one band is to be considered part of the picking process.

Exception No. 3: The opening of bales in the press room for pressing or recompressing.

Exception No. 4: The cleaning of baled cotton by brushing (manual only) where the process employed does not remove an appreciable quantity of lint.

Mechanical reconditioning operations should confine lint and "fly" to the reconditioning building and should be separated from cotton storage (or compress) by a standard fire wall without openings or by unobstructed clear spaces as outlined in Chapter 2.

6-4 Cutting and Welding.

6-4.1 Where cutting and welding operations are necessary, the precautions contained in NFPA 51, *Standard for the Design and Installation of Oxygen-Fuel Gas Systems for Welding, Cutting, and Allied Processes*, should be followed.

6-4.2 Welding, soldering, brazing, or cutting should be permitted only by the authorization of management. Proper precautions should be observed and should include the following:

- (a) A supervisor should be assigned to the operation.
- (b) The area should be made fire-safe.
- (c) Work should be removed to a safe area, where possible.
- (d) Where these operations are performed on equipment or building components that cannot be moved, there should be no storage below or within a 35-ft (10.7-m) radius.
- (e) Floors should be swept clean and wooden floors wet down within the 35-ft (10.7-m) radius.
- (f)* The cutting and welding equipment to be used should be in good operating condition and properly maintained.
- (g) Openings and cracks in wood construction should be tightly covered to prevent the passage of sparks.
- (h) All cotton bordering the area should be protected by flameproofed covers or otherwise shielded with metal or asbestos guards or curtains. The edges of the covers at the floor should be tight to prevent sparks from escaping. This precaution should extend to where several covers are used to protect a large storage pile.
- (i) All fire protection equipment should be in service and ready for immediate use.
- (j) A fire watch should be maintained and equipped with a portable extinguisher during these operations for not less than 1 hour following the completion of open flame operation.

6-5* Waste Disposal. Rubbish, trash, and other waste material should be disposed of at regular intervals. Approved waste cans with self-closing covers should be used where needed. Open fires and incinerator operations should be prohibited within 100 ft (30.5 m) of any cotton storage building.

6-6* Smoking. Smoking should be strictly prohibited. "No smoking" signs should be posted conspicuously in prohibited areas.

Exception: Smoking may be permitted in locations prominently designated as safe smoking areas.

6-7 Maintenance and Inspection.

6-7.1 Fire walls, fire doors, fire door guards, and floors should be maintained in good repair at all times.

6-7.2 NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, should be referenced for information on the maintenance and service of sprinkler systems and water supplies.

6-7.3 All portable and manual fire extinguishing equipment should be maintained and serviced.

6-7.4* As an aid in maintaining fire protection features and equipment in full service at all times, Figure A-6-7.4 provides a simple self-inspection form that contains a checklist of loss prevention principles. This sample form can be used without change or as a guide in establishing a specialized form to suit individual facilities. [See Figure A-6-7.4.]

6-8 Grass and Weeds. All dried grass and weeds should be kept clear of buildings for at least 50 ft (15.2 m).

Chapter 7 Referenced Publications

7-1 The following documents or portions thereof are referenced within this recommended practice and should be considered part of the recommendations of this document. The edition indicated for each reference is the current edition as of the date of the NFPA issuance of this document.

7-1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 10, *Standard for Portable Fire Extinguishers*, 1994 edition.

NFPA 13, *Standard for the Installation of Sprinkler Systems*, 1994 edition.

NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*, 1996 edition.

NFPA 18, *Standard on Wetting Agents*, 1995 edition.

NFPA 24, *Standard for the Installation of Private Fire Service Mains and Their Appurtenances*, 1995 edition.

NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 1995 edition.

NFPA 30, *Flammable and Combustible Liquids Code*, 1993 edition.

NFPA 51, *Standard for the Design and Installation of Oxygen-Fuel Gas Systems for Welding, Cutting, and Allied Processes*, 1992 edition.

NFPA 58, *Standard for the Storage and Handling of Liquefied Petroleum Gases*, 1995 edition.

NFPA 70, *National Electrical Code*, 1996 edition.

NFPA 72, *National Fire Alarm Code*, 1993 edition.

NFPA 80, *Standard for Fire Doors and Fire Windows*, 1995 edition.

NFPA 80A, *Recommended Practice for Protection of Buildings from Exterior Fire Exposures*, 1993 edition.

NFPA 220, *Standard on Types of Building Construction*, 1995 edition.

NFPA 251, *Standard Methods of Tests of Fire Endurance of Building Construction and Materials*, 1995 edition.

NFPA 505, *Fire Safety Standard for Powered Industrial Trucks Including Type Designations, Areas of Use, Maintenance, and Operation*, 1992 edition.

NFPA 600, *Standard on Industrial Fire Brigades*, 1996 edition.

NFPA 601, *Standard for Security Services in Fire Loss Prevention*, 1996 edition.

7-1.2 Other Publications.

7-1.2.1 ASTM Publication. American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19105.

ASTM E 119, *Standard Methods for Fire Tests of Building Construction and Materials*, 1995.

7-1.2.2 UL Publication. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062.

UL 263, *Standard for Safety Fire Tests of Fire Resistance of Building Construction and Materials*, 1992.

Appendix A Explanatory Material

This Appendix is not a part of the recommendations of this NFPA document but is included for informational purposes only.

A-1-3 Approved. The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization concerned with product evaluations that is in a position to determine compliance with appropriate standards for the current production of listed items.

A-1-3 Authority Having Jurisdiction. The phrase "authority having jurisdiction" is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

A-1-3 Listed. The means for identifying listed equipment may vary for each organization concerned with product evaluation, some of which do not recognize equipment as listed unless it is also labeled. The authority having jurisdiction should utilize the system employed by the listing organization to identify a listed product.

A-2-3.2 For a complete description of construction Types I, II, III, IV, and V, see NFPA 220, *Standard on Types of Building Construction*.

A-3-1 One building, compartment, or section classed as a fire division should not contain more than 10,000 bales of cotton if protected by a sprinkler system in accordance with Chapter 4, nor more than 5000 bales if not so protected. (See Section 2-3.)

A-4-1.3.5 Limited tests and actual fire experience indicate an initial low heat release; thus, sprinklers in the ordinary temperature range should offer some advantage by opening faster than those of intermediate or high temperature classifications under similar conditions.

A-4-6.4 For further information, see NFPA 13E, *Guide for Fire Department Operations in Properties Protected by Sprinkler and Standpipe Systems*.

A-5-6 In the case of buildings, sprinklered or unsprinklered, the clear space may be permitted to be reduced up to 50 percent if construction is fire-resistive or if facing walls are masonry and parapeted with adequately

Table A-1-3 Typical Cotton Bale Types and Approximate Sizes

Bale Type	Dimensions		Avg. Wt.		Volume		Density	
	(in.)	(mm)	(lb)	(kg)	(ft ³)	(m ³)	(lb/ft ³)	(kg/m ³)
Gin, flat	55 × 45 × 28	1397 × 1143 × 711	500	226.8	40.1	1.13	12.5	201
Modified gin, flat	55 × 45 × 24	1397 × 1143 × 610	500	226.8	34.4	0.97	14.5	234
Compressed, standard	57 × 29 × 23	1448 × 736 × 584	500	226.8	22.0	0.62	22.7	366
Gin, standard	55 × 31 × 21	1397 × 787 × 533	500	226.9	20.7	0.58	24.2	391
Compressed, universal	58 × 25 × 21	1475 × 635 × 533	500	226.8	17.6	0.50	28.4	454
Gin, universal	55 × 26 × 21	1397 × 660 × 533	500	226.8	17.4	0.49	28.7	463
Compressed, high density	58 × 22 × 21	1473 × 559 × 533	500	226.8	15.5	0.44	32.2	515

		WAREHOUSE NO.		COMPARTMENT NO.			
General Housekeeping		YES	NO	Fire Department		YES	NO
1. Inside Buildings				(a) Phone number prominently displayed at each phone?		<input type="checkbox"/>	<input type="checkbox"/>
(a)	Floor and dock areas clean of loose cotton and trash?	<input type="checkbox"/>	<input type="checkbox"/>	(b) Personnel instructed on procedure in case of fire?		<input type="checkbox"/>	<input type="checkbox"/>
(b)	Covered metal containers for loose cotton and trash?	<input type="checkbox"/>	<input type="checkbox"/>	Watch Service			
2. Outside Buildings				(a) Making regular rounds?		<input type="checkbox"/>	<input type="checkbox"/>
(a)	Surrounding areas free of dried grass, weeds, and combustible trash?	<input type="checkbox"/>	<input type="checkbox"/>	(b) All key stations punched?		<input type="checkbox"/>	<input type="checkbox"/>
Smoking				(c) Records checked, dated, and filed?		<input type="checkbox"/>	<input type="checkbox"/>
(a)	Evidence of smoking in unauthorized areas?	<input type="checkbox"/>	<input type="checkbox"/>	Fire Alarm Service			
(b)	Signs posted and readily visible?	<input type="checkbox"/>	<input type="checkbox"/>	(a) Automatic fire alarm system in service?		<input type="checkbox"/>	<input type="checkbox"/>
Electrical Equipment				(b) Manual pull stations clearly marked and accessible?		<input type="checkbox"/>	<input type="checkbox"/>
(a)	Extension cords prohibited?	<input type="checkbox"/>	<input type="checkbox"/>	(c) Date last tested?		<input type="checkbox"/>	<input type="checkbox"/>
(b)	Storage in contact with lights or wiring?	<input type="checkbox"/>	<input type="checkbox"/>	Manual Extinguishing Equipment Portable Extinguishers			
(c)	Wiring properly supported and undamaged?	<input type="checkbox"/>	<input type="checkbox"/>	1. Hand Units			
(d)	Circuits properly fused?	<input type="checkbox"/>	<input type="checkbox"/>	(a) Properly placed and accessible?		<input type="checkbox"/>	<input type="checkbox"/>
(e)	All panels, junction, switch, and receptacle boxes covered?	<input type="checkbox"/>	<input type="checkbox"/>	(b) Recharged within the last year?		<input type="checkbox"/>	<input type="checkbox"/>
Mechanical Equipment				(c) All in good condition?		<input type="checkbox"/>	<input type="checkbox"/>
(a)	Listed for fiber storage (Type DS, DY, ES, EE, EX, GS, or LPS)?	<input type="checkbox"/>	<input type="checkbox"/>	2. Containers and Buckets			
(b)	Spark-retardant mufflers maintained?	<input type="checkbox"/>	<input type="checkbox"/>	(a) Properly distributed?		<input type="checkbox"/>	<input type="checkbox"/>
(c)	Refueled outside at designated area?	<input type="checkbox"/>	<input type="checkbox"/>	(b) Kept full?		<input type="checkbox"/>	<input type="checkbox"/>
(d)	Stored outside when idle?	<input type="checkbox"/>	<input type="checkbox"/>	(c) Two buckets per barrel?		<input type="checkbox"/>	<input type="checkbox"/>
(e)	General condition and maintenance good?	<input type="checkbox"/>	<input type="checkbox"/>	3. Mobile Equipment			
Buildings				(a) Properly placed and protected from damage?		<input type="checkbox"/>	<input type="checkbox"/>
(a)	Fire walls in good repair, including around fire door openings?	<input type="checkbox"/>	<input type="checkbox"/>	(b) Charged and ready for service?		<input type="checkbox"/>	<input type="checkbox"/>
(b)	Fire doors in proper working condition and tested for ease of closing each week? (Overhead, roll-type doors should be tested at least annually.)	<input type="checkbox"/>	<input type="checkbox"/>	Inside Hose			
(c)	Fire door guards in place and maintained?	<input type="checkbox"/>	<input type="checkbox"/>	(a) Hose and nozzle attached to each?		<input type="checkbox"/>	<input type="checkbox"/>
(d)	Floor and exterior walls in good repair?	<input type="checkbox"/>	<input type="checkbox"/>	(b) Racked and in good condition?		<input type="checkbox"/>	<input type="checkbox"/>
(e)	Exterior wall openings have doors and windows in place that close properly and lock?	<input type="checkbox"/>	<input type="checkbox"/>	(c) Easily accessible and ready for use?		<input type="checkbox"/>	<input type="checkbox"/>
(f)	Space under grade floor, if any, closed off?	<input type="checkbox"/>	<input type="checkbox"/>	(d) Valves operate readily?		<input type="checkbox"/>	<input type="checkbox"/>
Storage Arrangements				Yard Hydrants and Hose Houses			
1. Storage blocks				(a) Readily accessible?		<input type="checkbox"/>	<input type="checkbox"/>
(a)	Within prescribed height [15 ft (4.6 m)]?	<input type="checkbox"/>	<input type="checkbox"/>	(b) Hose racked or reeled and in good condition?		<input type="checkbox"/>	<input type="checkbox"/>
(b)	Sprinkler heads unimpaired [18-in. (457-mm) clearance]?	<input type="checkbox"/>	<input type="checkbox"/>	(c) Nozzles, spanners, hydrant wrench available?		<input type="checkbox"/>	<input type="checkbox"/>
(c)	Block sizes limited to 700 bales pressed or 350 flat?	<input type="checkbox"/>	<input type="checkbox"/>	(d) Hydrants operable?		<input type="checkbox"/>	<input type="checkbox"/>
(d)	Tiered storage stable and secure?	<input type="checkbox"/>	<input type="checkbox"/>	(e) General condition: Good <input type="checkbox"/> Poor <input type="checkbox"/>			
2. Aisles				Note: 1 in. = 25.4 mm; 1 ft = 0.3048 m			
(a)	At least one main aisle 12 ft (3.7 m) or more in width?	<input type="checkbox"/>	<input type="checkbox"/>	REMARKS (Report on any unusual conditions and action taken):			
(b)	Cross or work aisles at least 4 ft (1.2 m) in width?	<input type="checkbox"/>	<input type="checkbox"/>				
(c)	Any damaged bales, broken bands, or wet stock?	<input type="checkbox"/>	<input type="checkbox"/>	Report by:		Date:	

Figure A-6-7.4 Sample loss prevention self-inspection form for baled cotton storage.

protected openings. This area reduction also may be permitted to be applied to noncombustible buildings of a type limited to corrugated iron or asbestos panel walls and roof on a steel frame.

A-5-7.1.2 Where hose reels are used, they should be able to be pulled easily by two persons.

A-5-8.2 The U.S. Department of Transportation (DOT) has safety jurisdiction over a major segment of the trucking industry, specifically those vehicles used in transportation for interstate or foreign commerce. Reference also should be made to NFPA 512, *Standard for Truck Fire Protection*, which incorporates many requirements of DOT's Federal Motor Carrier Safety Regulations for the benefit of those not subject to DOT safety jurisdiction.

A-6-2.2 Lift trucks are a common cause of fires in cotton warehouses, due mainly to the lack of maintenance and cleanliness and the alteration or improper substitution of fire safety features.

A-6-4.2(f) Personnel operating arc welding or cutting equipment should be protected from possible shock.

A-6-5 For additional details, see NFPA 82, *Standard on Incinerators and Waste and Linen Handling Systems and Equipment*.

A-6-6 The cooperation of employees is more easily secured where a reasonable smoking policy is adopted, with smoking allowed in specified locations where there is little hazard, at specified times, and under suitable supervision. Complete prohibition is likely to lead to surreptitious smoking in out-of-the-way locations where the hazard is most dangerous.

A-6-7.4 See Figure A-6-7.4.

Appendix B Guidelines for Fighting Fires in Baled Cotton

This Appendix is not a part of the recommendations of this NFPA document but is included for informational purposes only.

B-1 Introduction. The information contained in this appendix is a summary of knowledge gained over the years by cotton warehouse personnel, fire fighters, and insurance authorities in fighting fires in the Cotton Belt.

A baled cotton fire has peculiarities that should be understood and respected if a large loss is to be avoided with minimum danger to personnel. Automatic sprinklers, if properly designed and supplied, can be expected to control a baled cotton fire where storage methods outlined in this recommended practice are followed, but extinguishment should not be expected.

The primary rule for any fire is always to call the responding fire department first. Fighting fires of any type is a profession and, even where a well-trained private fire organization is available, professional aid should be effected as soon as possible, and plant personnel should not be unduly exposed to the peril.

The myriad of small fibers that make up a cotton bale, especially a naked bale or one wrapped in burlap, and cover its surface offer a highly vulnerable source of ignition as well as the potential for a rapid flamespread, also known as "flashover." A flashover is usually followed by a slower flamespread at the surface, then tenacious burrowing into the pile between bales and penetration of the interiors of

individual bales. High density bales are less vulnerable to a burrowing fire, but the possibility of such a fire should not be ignored.

B-2 Causes. Some of the causes of cotton fiber fires include breaking metal bands (ties) that strike other metallic objects resulting in sparks, fire-packed bales, electrical faults, mechanical equipment (defective lift trucks), friction (bale ties rubbing together, railroad boxcars), lightning, cutting and welding, and smoking. Sparks from bale ties and fire-packed bales appear to be the most prominent fire cause. Incendiarism and exposures are also a consideration.

B-3 Incipient Stage. If caught in the incipient stage, control can often be effected, provided the proper procedures are followed. Portable extinguishing equipment, such as containers and pails, or pressurized or pump-type water units, can be used to wet down the exterior of the bale quickly.

If small extinguishers are not successful, portable, wheeled, wetting agent tanks or standpipe hose, or both, should be used. The last resort is hose streams from outside hydrants. Extreme caution should be exercised when using straight hose streams, as the force of the stream could scatter the burning wads or portions of cotton over a wide area. Spray or fog nozzles are recommended, but, if not available, it might be possible to deflect a solid stream off the walls, roof, or other solid object.

Once the exterior of the bale(s) is fully wet down and fire is suppressed, the bales involved then should be removed to an outside, safe location for final extinguishment.

CAUTION: An obviously burning bale should never be dragged or mechanically moved down aisles, as this is likely to spread the fire to bales bordering the aisle. (See Section B-9.)

B-4 Active Stage in Sprinklered Buildings. If a fire progresses well beyond the incipient stage or involves more than a few bales and further firespread is likely, the building could readily prove untenable and dense smoke could quickly obscure vision. It then is best to have all personnel vacate the building to a point of safety. As drafts, including early venting through roofs and walls, are undesirable, it is essential to leave the building unventilated and close all doors and cut off all possible drafts to the building or section involved. This reduces available oxygen to the fire, and the dense smoke suppresses fire intensity. Drafts not only provide fresh air to increase fire intensity but also can blow heat away from the fire, opening sprinklers beyond the fire area and possibly overtaxing the available water to the sprinkler system.

The sprinkler system should be given a chance to do its job. DO NOT VENTILATE! Ventilating a cotton fire can cause it to flash out of control, spread with explosive violence, and open an excessive number of sprinklers.

After the fire is under control of the sprinkler system, the compartment door should be opened only enough to use fire hose or to enter and remove the cotton. The smoldering bales should be removed to the outside as soon as possible for individual attention. Extreme caution should be exercised when entering a fire area. Entry should be on the downwind side, if possible, to avoid creating draft conditions that could cause the fire to reignite. It is important to remain alert for gas explosions. If the fire appears to flare up again, the building should be vacated immediately.

and the doors again should be closed tightly and the sprinkler system should be allowed to regain control.

B-5 Sprinkler Failure. If the sprinkler system fails to maintain fire control, then hose streams should be used, preferably through door openings only large enough for the hose.

Where it is apparent that the fire is beyond the control of the sprinklers and the building is nearing the point of collapse, the control valve(s) to the sprinkler systems in the building or section involved should be shut off to conserve water for hose stream use.

B-6 Active Stage in Nonsprinklered Buildings. Immediately on arrival at the fire, all openings to the compartment involved should be closed.

As many hose lines as possible, preferably supplied with a wetting agent, should be available.

The doors should be opened only enough to allow the use of the hose in a spray-like fashion. Caution should be exercised to open these doors slowly to minimize the chance of an explosion. The doors on the opposite sides of the compartment should not be opened, which would allow a cross-draft. Only the door on the lee side, and not the windward side, of the building should be opened.

B-7 Cotton Yard Fires. Conditions in a cotton yard fire are not as controllable as those in a warehouse fire, since draft conditions are almost entirely dependent upon the climatic conditions at the time of the fire; and, if an adverse wind prevails, a small involvement can easily become a catastrophe. Preplanning is particularly important in this case. Upon arrival at a cotton yard fire, the following steps should be taken immediately:

(a) If available, fire department connection to the hydrants should be utilized.

(b) Hose lines should be laid out.

(c) Using divided stream nozzles, water should be applied ahead and downwind of the fire and then worked toward the fire.

(d) Bales and dunnage should be checked underneath for fire.

(e) It is important to remain alert for flying sparks.

(f) The nearby uninvolved cotton should be removed to create a fire break.

(g) Burned cotton should be removed to a segregated area.

B-8 After Watch. Where the fire-involved cotton has been removed and leaves behind undamaged stock, a minute and unobserved spark often causes a rekindling of the previous fire with disastrous results. The involved area should be inspected and carefully cleaned. Hose lines and fire department watch should be maintained until the area is known to be safe. Before leaving the scene of the fire, responsible plant personnel should be advised that after watch should be kept for at least 24 hours. One of the most disastrous fires on record could possibly have been prevented with adequate after watch following a minor involvement.

B-9 Salvage Operations. Salvage is important, and every precaution should be taken to protect the salvage. The usual severity of a fire in a cotton warehouse, along with the appearance of the charred bales, is misleading with respect to the amount of remaining salvage.

Water does not damage cotton, and if the charred bales are kept cool with hose streams until proper salvage operation is begun, the quantity of the loss can be reduced substantially.

After the fire is brought under control, all bales involved should be removed to a safe outside location as quickly as possible and practicable. Each bale then should be handled individually in order to effect complete extinguishment. This is best accomplished by the use of small hose lines or barrels and buckets, using a wetting agent known as wet water.

WARNING: DO NOT REMOVE THE BANDS OR WIRES FROM THE BALES. To do so exposes more lint to the fire and threatens the loss of the entire bale.

Salvage crews should be ready to move the cotton out of the involved shed as rapidly as possible. *Extreme* caution should be exercised in preparing and watching the path along which the burned bales are removed from the involved shed. Burning fibers of cotton are easily blown from the bale, especially in the haste and excitement of moving the bales outside. It might be necessary to move the uninvolved bales away from the exit route (or from the entire compartment) or even to make a hole in the side of the compartment. The spread of fire along the exit route caused by burning bales is not uncommon! The burning bales should be wetted down and moved to a safe, segregated place as soon as possible for individual attention.

The following are steps to be taken in the salvage operation:

(a) An open area, without exposures, into which the burning bales can be moved should be selected.

(b) A salvage crew should be stationed at the yard.

(c) A good supply of wetting agent should be available.

(d) A good supply of water should be available.

(e) Containers, pails, and stirrup pump-type extinguishers should be available, filled with wet water.

(f) Burning bales should be wet down and removed from the fire area as soon as possible. They should be placed approximately 3 ft (0.9 m) apart in an open area away from other exposures.

(g) Care should be exercised in removing these bales so as not to start another fire in the process. If the side of the compartment is metal-clad or frame, it might be best to remove a portion of the side so that the cotton can be removed. Some warehouse personnel take the time to remove cotton from those compartments through which the burning bales travel before salvage operations are allowed to start. If there is any question regarding additional exposures, they should be removed, if possible, before moving the burning bales.

(h) Any outside blaze on the bale should be knocked down. The wet water should be applied to each smoldering spot on the bale. Often a handful of cotton soaked in the wet water can be applied directly on or into the smoldering spot. Cotton fires burrow into the bale, so it is necessary to apply the wet water as far into the hole as possible, soaking the area thoroughly. In order to be certain the fire is out, the burned cotton should be removed from each hot spot while applying wet water to the hole. When the area around the spot is no longer warm, it can be assumed that the fire has been extinguished.

(i) The bands from the bales should not be removed. To do so exposes more lint to the fire, and the bale will probably be a complete loss.

(j) Bales involved in a fire should be closely watched for at least 5 days after the last spark is believed to have been extinguished.

B-10 Fire-packed Bales. During the cotton ginning operation, sparks, caused by stones, metal, or other foreign objects in the seed cotton striking metal parts of the gin, can ignite the fibers. Occasionally, a fire immediately erupts, but often the smoldering lint is carried onto the press box where it can be packed, undetected, into the bale. Usually the fire burns through to the outside of the bale within a few hours, but it can remain undetected for several days. Sometimes the odor is noticeable or the bale feels excessively warm.

These bales are known as fire-packed bales and are a major cause of fires in baled cotton.

The recommended procedure for handling and extinguishing fire-packed bales is as follows:

(a) All known or suspect fire-packed bales should be stored in the open and segregated from buildings and other storage. They should be separated about 3 ft (0.9 m) from other such bales.

(b) These bales should be under constant surveillance to detect fire as soon as it moves to the surface.

(c) A supply of an approved wetting agent and at least one stirrup pump should be available at all times.

(d) When fire is detected, the area around the hot spot should be wetted immediately to prevent the spread of the fire. The hot spot then should be saturated with wet water. The burned cotton should be removed by hand while constantly applying water to the hole. This procedure should be continued until no warm areas are detected. It is not uncommon for several fires to be packed into a single bale.

(e) **DO NOT REMOVE THE BANDS FROM THE BALE**, as this exposes more cotton fibers to ignition and usually results in the total loss of the bale.

(f) Fire-packed bales or bales suspected of being fire-packed should remain in quarantine and under surveillance for at least 5 days. After this time, they can be considered to be safe and handled in the regular manner.

NOTE: There is no set time after which a fire can be considered extinguished in a bale, as this depends on the thoroughness of extinguishment. However, 5 days after the fire is believed to have been extinguished is generally considered to be a rule of thumb safe period.

Appendix C Referenced Publications

C-1 The following documents or portions thereof are referenced within this recommended practice for informational purposes only and thus are not considered part of the recommendations of this document. The edition indicated for each reference is the current edition as of the date of the NFPA issuance of this document.

C-1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 13E, *Guide for Fire Department Operations in Properties Protected by Sprinkler and Standpipe Systems*, 1995 edition.

NFPA 82, *Standard on Incinerators and Waste and Linen Handling Systems and Equipment*, 1994 edition.

NFPA 220, *Standard on Types of Building Construction*, 1995 edition.

NFPA 512, *Standard for Truck Fire Protection*, 1994 edition.

Index

© 1996 National Fire Protection Association, All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document which it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of the National Fire Protection Association, Inc.

-A-	
Access, fire fighting	4-6.1, 5-4.2
Active stage fires	B-4, B-6
Administration	6-1
After watch	B-8
Aisles	3-1, 3-3
Alarm service	4-5
Approved (definition)	1-3, A-1-3
Authority having jurisdiction (definition)	1-3, A-1-3
-B-	
Baled cotton	
Causes of fires in	1-2.2, B-2
Definition	1-3, Table A-1-3
Fighting fires in	App. B
Bales	
Fire-packed	see Fire-packed bales
Naked	B-1
Definition	1-3
Block storage	3-1 to 3-2, A-3-1
Definitions	1-3, 5-2
In yards	5-4.4 to 5-4.5
Buildings	
Administration	6-1
Boilers and similar equipment in	6-3.3.1
Clear spaces between	2-3, 6-3.3.2, A-2-3.2
Construction	Chap. 2, A-2-3.2
Electrical installation	6-3.3
Fire protection self-inspection	6-7.4
Maintenance	6-7.1
Reconditioning and repairing in	6-3.3
Sprinklered, fires in	B-4
Unsprinklered, fires in	B-6
-C-	
Ceilings, clearances from	3-6.5
Clear spaces	
Between buildings	2-3, A-2-3.2
Reconditioning operations	6-3.3.2
Yard storage	5-4.5, 5-6, A-5-6

Clearances, storage 3-6, 4-1.4, 5-7.1.1
Cold cotton (definition) 1-3
Communications, emergency 5-7.5
Cotton
 Baled *see* Baled cotton
 Cold (definition) 1-3
Cutting and welding 6-4, A-6-4.2(f), B-2

-D-

Definitions 1-3, 5-2, A-1-3
Designated yard (definition) 5-2
Diesel fuel 6-2.1.1
Doors *see also* Fire doors
 Clearances from 3-6.3 to 3-6.4
Draft curtains 2-2
Dry chemical extinguishers 4-4.2.1, 5-7.4

-E-

Electrical systems and equipment 3-6.1 to 3-6.2, 6-3.1
Emergency communications 5-7.5
Emergency planning 4-6, 5-7.6, A-4-6.4
Emergency smoke and heat venting 2-2
Extinguishing agent *see* Wetting agent

-F-

Fire brigades 4-6.2
Fire divisions 2-3, A-2-3.2
Fire doors
 Clearances from 3-6.3
 Guards for 2-3.4
 Maintenance 6-7.1
Fire emergency planning 4-6, 5-7.6, A-4-6.4
Fire extinguishers, portable 4-4.2 to 4-4.4, B-3
Fire inspections 4-6.4, A-4-6.4
Fire protection Chap. 4, A-4
 Clearances from equipment 3-6.4, 4-1.4
 Inspection of 6-7.4
 Manual inside 4-4
 Yard storage 5-7, A-5-7.1.2
Fire walls 2-3.2 to 2-3.3, 6-3.3.1 to 6-3.3.2, 6-7.1, A-2-3.2
Fire watch 4-6.5, 5-8.3
 After watch B-8
Fire-packed bales 3-4, 5-5, B-2, B-10
 Definition 1-3
Fires in baled cotton, fighting App. B
Flameover 4-2.3, B-1
 Definition 1-3
Flashover *see* Flameover
Freshly ginned bales *see* Fire-packed bales
Fuel storage and handling 6-2.1.1 to 6-2.1.2, 6-2.1.4, 6-2.2

-G-

Gasoline fuel 6-2.1.1
General information 1-2
Grass, clearing of 5-6(h), 6-8
Group of yards 5-4.4 to 5-4.5
 Definition 5-2
Guard watch service 5-8.3

-H-

Haulage, inter-plant 6-2.3
Heat venting 2-2
Hoses, use of 3-6.5, 4-2.2, 4-4.1, 4-6.3, B-3, B-6 to B-7, B-9
Hydrants 4-3, 4-4.1(a), 5-3, 5-7.1, B-7(a)

-I-

Incipient stage fires B-3
Industrial trucks 6-2.1 to 6-2.2, A-6-2.2, B-2
Inspections
 Building self-inspection 6-7.4, A-6-7.4
 Fire 4-6.4, A-4-6.4
Internal combustion equipment 5-8.2, A-5-8.2

-L-

Labeled (definition) 1-3
Lightning B-2
Lights and light fixtures
 Clearances from 3-6.1
 Portable 6-3.1(b)
Listed (definition) 1-3, A-1-3
LPG fuel containers 6-2.1.2

-M-

Maintenance
 Building 6-7.1
 Fire extinguishing equipment 6-7.3 to 6-7.4
 Mechanical handling equipment 6-2.2, A-6-2.2
 Yard storage 5-8, A-5-8.2
Manual inside fire protection 4-4
Mechanical handling equipment 6-2, A-6-2.2, B-2

-N-

Naked bales B-1
 Definition 1-3

-O-

Open flame heating devices 6-3.2
Operations
 Mechanical handling equipment 6-2.2, A-6-2.2
 Yard storage 5-8, A-5-8.2

-P-

Protected yards 5-4.4 to 5-4.5
 Definition 5-2

-Q-

Quarantine yards 5-5
 Definition 5-2

-R-

Racks
 Definition 1-3
 Storage 3-2.2 to 3-2.4, 4-1.3
Reconditioning 6-3.3
Referenced publications Chap. 7, App. C
Roof
 Clearances from 3-6.5
 Vents 2-2
Rows 5-4.3, 5-4.5 to 5-4.6
 Definition 5-2

-S-

Salvage operations B-9
Scope of standard 1-1

Shops and equipment	6-3.3
Should (definition)	1-3
Smoke venting	2-2
Smoking prohibition	5-8.1, 6-6, A-6-6, B-2
Spark arresters	5-8.2, 6-2.3
Sprinkler systems	2-1.2, 3-1, 4-1, 4-6.3, A-3-1, A-4-1.3.5
Active stage fires in sprinklered buildings	B-4
Clearances from	3-6.4, 4-1.4
Failure	B-5
Hose system supplied by	4-4.1(c) to 4-4.1(d)
Water supply for	4-2, 4-6.3
Waterflow alarms	4-5
Storage	Chap. 3, A-3-1
Block	<i>see</i> Block storage
Clearances	3-6, 4-1.4, 5-7.1.1
Commodities other than cotton	3-5
Tiered	<i>see</i> Tiered storage
Yard	<i>see</i> Yard storage
Storage batteries, charging equipment for	6-2.1.3

-T-

Telephones, clearances from	3-6.4
Tiered storage	3-1, 4-1.3, 5-4.1, A-3-1
Definition	1-3
Tractors	6-2.3
Trucks, industrial	6-2.1 to 6-2.2, A-6-2.2

-U-

Unprotected storage	5-4.4 to 5-4.5
Definition	5-2

-V-

Vehicles, motorized	5-7.4, 6-2.1 to 6-2.2, 6-2.4, A-6-2.2
Ventilation, of cotton fire	B-4
Venting, emergency smoke and heat	2-2

-W-

Walls, fire	<i>see</i> Fire walls
Waste disposal	6-5, A-6-5
Water as extinguishing agent	4-4.2.1, B-3, B-9
Water supply	4-2, 4-4.1, 4-6.3
Yard storage	5-7.1.3, 5-7.3
Waterflow alarms	4-5
Weeds, clearing of	5-6(h), 6-8
Welding and cutting	6-4, A-6-4.2(f), B-2
Wetting agent	4-4.2.1, B-3, B-10(c)
Wetting agent extinguishing units	4-4.3, 5-7.2

-Y-

Yard storage	Chap. 5, A-5
Arrangements	5-4
Clear space requirements	5-6, A-5-6
Definitions	1-3, 5-2
Fire protection	5-7, A-5-7.1.2
Fires	B-7
Maintenance and operations	5-8, A-5-8.2
Quarantine	5-5
Site	5-3

The NFPA Codes and Standards Development Process

Since 1896, one of the primary purposes of the NFPA has been to develop and update the standards covering all areas of fire safety.

Calls for Proposals

The code adoption process takes place twice each year and begins with a call for proposals from the public to amend existing codes and standards or to develop the content of new fire safety documents.

Report on Proposals

Upon receipt of public proposals, the technical committee members meet to review, consider, and act on the proposals. The public proposals – together with the committee action on each proposal and committee-generated proposals – are published in the NFPA's Report on Proposals (ROP). The ROP is then subject to public review and comment.

Report on Comments

These public comments are considered and acted upon by the appropriate technical committees. All public comments – together with the committee action on each comment – are published as the Committee's supplementary report in the NFPA's Report on Comments (ROC).

The committee's report and supplementary report are then presented for adoption and open debate at either of NFPA's semi-annual meetings held throughout the United States and Canada.

Association Action

The Association meeting may, subject to review and issuance by the NFPA Standards Council, (a) adopt a report as published, (b) adopt a report as amended, contingent upon subsequent approval by the committee, (c) return a report to committee for further study, and (d) return a portion of a report to committee.

Standards Council Action

The Standards Council will make a judgement on whether or not to issue an NFPA document based upon the entire record before the Council, including the vote taken at the Association meeting on the technical committee's report.

Voting Procedures

Voting at an NFPA Annual or Fall Meeting is restricted to members of record for 180 days prior to the opening of the first general session of the meeting, except that individuals who join the Association at an Annual or Fall Meeting are entitled to vote at the next Fall or Annual Meeting.

"Members" are defined by Article 3.2 of the Bylaws as individuals, firms, corporations, trade or professional associations, institutes, fire departments, fire brigades, and other public or private agencies desiring to advance the purposes of the Association. Each member shall have one vote in the affairs of the Association. Under Article 4.5 of the Bylaws, the vote of such a member shall be cast by that member individually or by an employee designated in writing by the member of record who has registered for the meeting. Such a designated person shall not be eligible to represent more than one voting privilege on each issue, nor cast more than one vote on each issue.

Any member who wishes to designate an employee to cast that member's vote at an Association meeting in place of that member must provide that employee with written authorization to represent the member at the meeting. The authorization must be on company letterhead signed by the member of record, with the membership number indicated, and the authorization must be recorded with the President of NFPA or his designee before the start of the opening general session of the Meeting. That employee, irrespective of his or her own personal membership status, shall be privileged to cast only one vote on each issue before the Association.

Sequence of Events Leading to Publication of an NFPA Committee Document

Call for proposals to amend existing document or for recommendations on new document.



Committee meets to act on proposals, to develop its own proposals, and to prepare its report.



Committee votes on proposals by letter ballot. If two-thirds approve, report goes forward.
Lacking two-thirds approval, report returns to committee.



Report is published for public review and comment. (Report on Proposals - ROP)



Committee meets to act on each public comment received.



Committee votes on comments by letter ballot. If two-thirds approve, supplementary report goes forward. Lacking two-thirds approval, supplementary report returns to committee.



Supplementary report is published for public review. (Report on Comments - ROC).



NFPA membership meets (Annual or Fall Meeting) and acts on committee report (ROP and ROC).



Committee votes on any amendments to report approved at NFPA Annual or Fall Meeting.



Complaints to Standards Council on Association action must be filed
within 20 days of the NFPA Annual or Fall Meeting.



Standards Council decides, based on all evidence, whether or not to issue standard
or to take other action, including hearing any complaints.



Appeals to Board of Directors on Standards Council action must be filed
within 20 days of Council action.

FORM FOR PROPOSALS ON NFPA TECHNICAL COMMITTEE DOCUMENTS

Mail to: Secretary, Standards Council

National Fire Protection Association, 1 Batterymarch Park, Quincy, Massachusetts 02269-9101

Fax No. 617-770-3500

Note: All proposals must be received by 5:00 p.m. EST/EDST on the published proposal-closing date.

If you need further information on the standards-making process, please contact the
Standards Administration Department at 617-984-7249.

Date 9/18/93 Name John B. Smith Tel. No. 617-555-1212

Company _____

Street Address 9 Seattle St., Seattle, WA 02255

Please Indicate Organization Represented (if any) Fire Marshals Assn. of North America

1. a) NFPA Document Title National Fire Alarm Code NFPA No. & Year NFPA 72, 1993 ed.

b) Section/Paragraph 1-5.8.1 (Exception No.1)

2. Proposal recommends: (Check one) ☐ new text
☐ revised text
☒ deleted text

FOR OFFICE USE ONLY

Log # _____

Date Rec'd _____

3. Proposal (include proposed new or revised wording, or identification of wording to be deleted): (Note: Proposed text should be in legislative format: i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).

Delete exception.

4. Statement of Problem and Substantiation for Proposal: (Note: State the problem that will be resolved by your recommendation; give the specific reason for your proposal including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

A properly installed and maintained system should be free of ground faults. The occurrence of one or more ground faults should be required to cause a "trouble" signal because it indicates a condition that could contribute to future malfunction of the system. Ground fault protection has been widely available on these systems for years and its cost is negligible. Requiring it on all systems will promote better installations, maintenance and reliability.

5. ☒ This Proposal is original material. (Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought, or research and, to the best of his/her knowledge, is not copied from another source.)

☐ This Proposal is not original material; its source (if known) is as follows: _____

Note 1: Type or print legibly in black ink.

Note 2: If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.

I hereby grant NFPA the non-exclusive, royalty-free rights, including non-exclusive, royalty-free rights in copy-right, in this proposal and I understand that I acquire no rights in any publication of NFPA in which this proposal in this or another similar or analogous form is used.

John B. Smith
Signature (Required)

PLEASE USE SEPARATE FORM FOR EACH PROPOSAL

FORM FOR PROPOSALS ON NFPA TECHNICAL COMMITTEE DOCUMENTS

Mail to: Secretary, Standards Council

National Fire Protection Association, 1 Batterymarch Park, Quincy, Massachusetts 02269-9101

Fax No. 617-770-3500

Note: All proposals must be received by 5:00 p.m. EST/EDST on the published proposal-closing date.

If you need further information on the standards-making process, please contact the
Standards Administration Department at 617-984-7249.

Date _____ Name _____ Tel. No. _____

Company _____

Street Address _____

Please Indicate Organization Represented (if any) _____

1. a) NFPA Document Title _____ NFPA No. & Year _____

b) Section/Paragraph _____

2. Proposal Recommends: (Check one) ☐ new text
☐ revised text
☐ deleted text

FOR OFFICE USE ONLY

Log # _____

Date Rec'd _____

3. Proposal (include proposed new or revised wording, or identification of wording to be deleted): (Note: Proposed text should be in legislative format: i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).

4. Statement of Problem and Substantiation for Proposal: (Note: State the problem that will be resolved by your recommendation; give the specific reason for your proposal including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

5. ☐ This Proposal is original material. (Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought, or research and, to the best of his/her knowledge, is not copied from another source.)

☐ This Proposal is not original material; its source (if known) is as follows: _____

Note 1: Type or print legibly in black ink.

Note 2: If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.

I hereby grant NFPA the non-exclusive, royalty-free rights, including non-exclusive, royalty-free rights in copy-right, in this proposal and I understand that I acquire no rights in any publication of NFPA in which this proposal in this or another similar or analogous form is used.

Signature (Required)

PLEASE USE SEPARATE FORM FOR EACH PROPOSAL

Cut here




NO POSTAGE
NECESSARY
IF MAILED
IN THE
UNITED STATES

BUSINESS REPLY MAIL
FIRST CLASS MAIL PERMIT NO. 3376 BOSTON, MA

POSTAGE WILL BE PAID BY ADDRESSEE

NATIONAL FIRE PROTECTION ASSOCIATION
1 BATTERYMARCH PARK
PO BOX 9101
QUINCY MA 02269-9904




NO POSTAGE
NECESSARY
IF MAILED
IN THE
UNITED STATES

BUSINESS REPLY MAIL
FIRST CLASS MAIL PERMIT NO. 3376 BOSTON, MA

POSTAGE WILL BE PAID BY ADDRESSEE

NATIONAL FIRE PROTECTION ASSOCIATION
1 BATTERYMARCH PARK
PO BOX 9101
QUINCY MA 02269-9904



NO POSTAGE
NECESSARY
IF MAILED
IN THE
UNITED STATES

BUSINESS REPLY MAIL
FIRST CLASS MAIL PERMIT NO. 3376 BOSTON, MA

POSTAGE WILL BE PAID BY ADDRESSEE

NATIONAL FIRE PROTECTION ASSOCIATION
1 BATTERYMARCH PARK
PO BOX 9101
QUINCY MA 02269-9904
Attn: Product Development



Bibliography of NFPA Standards

- 1 Fire Prevention Code
- 10 Portable Extinguishers
- 10R Portable Fire Extinguishing Equipment in Dwellings
- 11 Low-Expansion Foam
- 11A Medium- and High-Expansion Foam Systems
- 11C Mobile Foam Apparatus
- 12 Carbon Dioxide Systems
- 12A Halon 1301 Systems
- 13 Sprinkler Systems
- 13D Sprinkler Sys., Dwellings
- 13E Sprinkler Prop., F.D. Operations in
- 13R Sprinkler Sys., Res. Occ. up to and Including 4 Stories
- 14 Standpipe, Hose Systems
- 15 Water Spray Fixed Systems
- 16 Deluge Foam-Water Systems
- 16A Closed Head Foam-Water Sprinkler Systems
- 17 Dry Chem. Ext. Systems
- 17A Wet Chem. Ext. Systems
- 18 Wetting Agents
- 20 Centrifugal Fire Pumps
- 22 Water Tanks
- 24 Private Fire Service Mains
- 25 Water-Based Fire Prot. Systems
- 30 Flam. Liquids Code
- 30A Automotive and Marine Service Station Code
- 30B Aerosol Products
- 31 Oil-Burning Equipment
- 32 Drycleaning Plants
- 33 Spray Application
- 34 Dipping and Coating Processes
- 35 Organic Coatings
- 36 Solvent Extraction Plants
- 37 Combustion Engines and Gas Turbines
- 40 Motion Picture Film
- 40E Pyroxylin Plastic
- 43B Organic Peroxide Formulations
- 43D Pesticides, Storage
- 45 Laboratories Using Chemicals
- 46 Forest Products, Storage
- 49 Hazardous Chemicals Data
- 50 Bulk Oxygen Systems
- 50A Gaseous Hydrogen Systems
- 50B Liquefied Hydrogen Systems
- 51 Welding, Cutting and Allied Processes
- 51A Acetylene Charging Plants
- 51B Cutting and Welding Processes
- 52 CNG Vehicular Fuel Systems
- 53 Oxy. Atmospheres, Fires in
- 54 Nat'l Fuel Gas Code
- 55 Compressed and Liquefied Gases in Portable Cylinders
- 57 LNG Vehicular Fuel Systems
- 58 LP-Gas Storage
- 59 LP-Gas, Utility Plants
- 59A LN-Gas, Stg., Handling
- 61 Agricultural and Food Products Facilities
- 65 Aluminum Processing
- 68 Venting of Deflagrations
- 69 Explosion Prev. Systems
- 70 *National Electrical Code*
- 70B Elect. Equip. Maint.
- 70E Electrical Safety in Employee Work
- 72 National Fire Alarm Code
- 73 Residential Elect. Maint. for Dwellings
- 75 Electronic Computer Systems
- 77 Static Electricity
- 79 Elect. Std. for Ind. Machinery
- 80 Fire Doors and Fire Windows
- 80A Exterior Fire Exposure, Prot. from
- 82 Incinerators, Systems & Equip.
- 86 Ovens and Furnaces
- 86C Ind. Furn., Sp. Processing
- 86D Ind. Furnaces, Vacuum
- 88A Parking Structures
- 88B Repair Garages
- 90A Air Conditioning Systems
- 90B Warm Air Htg., Air Cond.
- 91 Exhaust Syst. for Air Conveying of Materials
- 92A Smoke-Control Systems
- 92B Smoke Mgmt. Syst. in Malls, Atria, Large Areas
- 96 Commercial Cooking Operations
- 97 Heating Terms, Glossary
- 99 Health Care Facilities
- 99B Hypobaric Facilities
- 101* *Life Safety Code*
- 101A Alt. Approaches to Life Safety
- 102 Grandstands, Folding/Telescopic Seating, Tents, and Membrane Struct.
- 105 Smoke-Control Door Assemblies
- 110 Emer., Standby Power Systems
- 111 Stored Electrical Energy Emer. & Standby Power Systems
- 115 Laser Fire Protection
- 120 Coal Preparation Plants
- 121 Self-Propelled & Mobile Surface Mining Equip.
- 122 Underground Metal and Nonmetal Mines
- 123 Undergr. Bituminous Coal Mines
- 130 Fixed Guideway Transit Sys.
- 150 Racetrack Stables
- 170 Fire Safety Symbols
- 203 Roof Coverings/Roof Deck
- 204M Smoke, Heat Venting
- 211 Chimneys, Fireplaces, Vents
- 214 Water Cooling Towers
- 220 Types Bldg. Construction
- 231 General Storage
- 231C Rack Storage of Mat'ls.
- 231D Rubber Tires, Storage
- 231E Baled Cotton, Storage
- 231F Roll Paper, Storage
- 232 Records, Prot.
- 232A Archives and Records Centers
- 241 Construction, Alteration, and Demolition Operations
- 251 Bldg. Constr. & Mat'ls., Fire Tests
- 252 Door Assem., Fire Tests of
- 253 Floor Covering Systems, Test for
- 255 Bldg. Mat'ls., Burning Character
- 256 Roof Coverings, Tests of
- 257 Window Assemblies, Tests of
- 258 Smoke Generation, Test of
- 259 Heat of Bldg. Mat'ls., Test for
- 260 Cig. Ignition Resistance—Components of Furniture, Tests for
- 261 Cig. Ignition Resistance—Uphol. Furn. Assem., Tests for
- 262 Wires and Cables, Test for Fire and Smoke Char. of
- 263 Heat & Smoke Release Rates, Test for
- 264 Heat-Release Rates Using Oxygen-Consumption Calorimeter, Test for
- 264A Heat Release Rates—Uphol. Furn. Comp. & Mattresses
- 265 Textile Wall Coverings—Room Fire Growth Contribution, Tests for
- 266 Uphol. Furn. Exp. to Flaming Ignition Sources, Test for
- 267 Mattress and Bedding Exp. to Flaming Ignition Source, Test for
- 268 Ignitibility of Exterior Wall Assemblies, Test for
- 269 Toxic Potency Data for Fire Hazard Modeling, Test for
- 291 Fire Hydrants
- 295 Wildfire Control
- 297 Communications Systems
- 298 Foam Chem. for Class A Fuels/Rural Suburban
- 299 Wildfire, Protection Life and Property from
- 302 Pleasure and Comm. Motor Craft
- 303 Marinas and Boatyards
- 306 Vessels, Gas Hazards on
- 307 Marine Terminals, Piers, Wharves
- 312 Vessels, Constr., Repair
- 318 Cleanrooms
- 321 Class. Flam. Liquids
- 325 Prop. of Flam. Liquids, Gases, Solids
- 326 Underground Storage Tanks, Safe Entry
- 327 Cleaning Small Tanks
- 328 Manholes, Sewers, Flam. Liquids and Gases in
- 329 Flam. and Com. Liquid, Underground Releases
- 385 Tank Vehicles
- 386 Portable Shipping Tanks
- 395 Farms, Storage Flam. Liquids
- 402M Aircraft Rescue, Fire Fighting
- 403 Aircraft Rescue Services
- 407 Aircraft Fuel Servicing
- 408 Aircraft Extinguishers
- 409 Aircraft Hangars
- 410 Aircraft Maintenance
- 412 Eval., Foam Equip. for Aircraft
- 414 Aircraft Rescue Vehicles
- 415 Aircraft Fueling Ramp Drainage
- 416 Airport Terminals
- 417 Aircraft Loading Walkways
- 418 Heliports
- 419 Airport Water Supply Systems
- 422 Aircraft Accident Response
- 423 Aircraft Engine Test Facilities
- 424M Airport/Community Emerg. Planning
- 430 Liquid/Solid Oxidizers
- 471 Responding to Haz. Mat. Incidents
- 472 Haz. Mat. Resp. Prof. Comp.
- 473 Competencies for EMS Personnel
- 480 Magnesium
- 481 Titanium
- 482 Zirconium
- 485 Lithium Metal
- 490 Ammonium Nitrate
- 491M Haz. Chem. Reactions
- 495 Explosive Materials
- 496 Purged Enclosures, Elec. Equip.
- 497A Class I Haz. Locations for Elec. Inst.
- 497B Class II Haz. Locations for Elec. Inst. in Chem. Process Areas
- 497M Gases, Vapors Dusts for Elec. Equip. in Haz. Loc.
- 498 Explosives Motor Vehicle Term.
- 501A Manufactured Home Instal., Sites
- 501C Recreational Vehicles
- 501D Recreational Vehicle Parks
- 502 Highways, Tunnels, Bridges
- 505 Powered Industrial Trucks
- 512 Truck Fire Protection
- 513 Motor Freight Terminals
- 550 Fire Safety Concepts Tree
- 560 Ethylene Oxide
- 600 Industrial Fire Brigades
- 601 Guard Service
- 650 Pneumatic Conveying Systems
- 651 Aluminum Powder
- 654 Chemical, Dye, Pharm., and Plastics Indust.
- 655 Sulfur Fires and Explosions
- 664 Wood Processing, Woodworking
- 701 Textiles, Films, Fire Tests
- 703 Fire-Ret. Treat. of Bldg. Mat'ls.
- 704 Fire Hazards of Materials
- 705 Field Flame Test for Textiles and Films
- 780 Lightning Protection Systems
- 801 Radioactive Materials Facilities
- 802 Nuclear Research Reactors
- 803 Light Water Nuclear Power Plants
- 804 Adv. Light Water Reactor Electric Generating Plants
- 820 Wastewater Facilities
- 850 Electric Generating Plants
- 851 Hydroelectric Generating Plants
- 901 Incident Reporting, Fire Prot. Data
- 902M Field Incident Manual
- 903 Property Survey Guide
- 904 Incident Follow-up Report Guide
- 906 Fire Incident Field Notes
- 910 Libraries and Library Collections
- 911 Museums and Museum Collections
- 912 Places of Worship
- 914 Fire Prot. in Historic Struc.
- 921 Fire and Explosion Investigations
- 1000 Prof. Qual. Accreditation and Cert. Sys.
- 1001 Fire Fighter Prof Qual.
- 1002 F.D. Vehicle Driver Prof. Qual.
- 1003 Airport Fire Fighter Prof. Qual.
- 1021 Fire Officer Prof. Qual.
- 1031 Fire Inspector Prof. Qual.
- 1033 Fire Investigator Prof. Qual.
- 1035 Public Fire Educator Prof. Qual.
- 1041 Fire Instructor Prof. Qual.
- 1051 Wildland Fire Fighter Prof. Qual.
- 1122 Model Rocketry
- 1123 Fireworks Display
- 1124 Fireworks, Mfg., Trans., Stge
- 1125 Model Rocket/High Power Rocket Motors, Mfg.
- 1126 Pyrotechnics Before Proximate Audience
- 1127 High Power Rocketry
- 1141 Planned Building Groups
- 1201 Devel. of FP Services for Public
- 1221 Public Fire Serv. Comm. Sys.
- 1231 Suburban & Rural Water Supplies
- 1401 Training Reports, Records
- 1402 Building Training Centers
- 1403 Live Fire Training Evolutions
- 1404 FD SCBA Program
- 1405 Land-Based Fire Fighters Who Respond to Marine Vessel Fires
- 1406 Outside Live Fire Training Evolutions
- 1410 Initial Fire Attack
- 1420 Warehouse Occupancies
- 1452 Dwelling Fire Safety Surveys
- 1470 Search and Rescue, Struct. Collapse
- 1500 Fire Dept. Occupational Safety and Health Prog.
- 1521 Fire Dept. Safety Officer
- 1561 F.D. Incident Management Syst.
- 1581 F.D. Infection Control Program
- 1582 Medical Requirements for Fire Fighters
- 1600 Disaster Management
- 1901 Pumper Fire Apparatus
- 1902 Initial Attack Fire Apparatus
- 1903 Mobile Water Supply Fire Apparatus
- 1904 Aerial Ladder & Elev. Platform
- 1906 Wildland Fire Apparatus
- 1911 Pumps on F.D. Apparatus, Tests of
- 1914 F.D. Aerial Devices, Testing
- 1921 Portable Pumping Units
- 1922 Self-Contained Pumping Units
- 1931 Fire Dept. Ground Ladders, Design
- 1932 Fire Dept. Ground Ladders, Use
- 1961 Fire Hose
- 1962 Fire Hose Care, Use
- 1963 Fire Hose Connections
- 1964 Spray Nozzles (Shutoff and Tip)
- 1971 Prot. Clothing, Structural Fire Fighting
- 1972 Helmets, Structural Fire Fighting
- 1973 Gloves, Structural Fire Fighting
- 1974 Prot. Footwear, Struc. Fire Fighting
- 1975 Station/Work Uniforms for FF
- 1976 Prot. Clothing - Proximity Fire Fighting
- 1977 Prot. Clothing - Wildland Fire Fighting
- 1981 Self-Contained Breathing App.
- 1982 Personal Alert Safety Systems for Fire Fighters
- 1983 Life Safety Rope and Sys. Comp.
- 1991 Vapor-Protective Suits for Haz. Chem. Emergencies
- 1992 Liquid Splash-Protective Suits for Haz. Chem. Emergencies
- 1993 Support Function Prot. Clothing for Haz. Chem. Oper.
- 1999 Prot. Clothing - Medical Emerg. Oper.
- 2001 Clean Agent Ext. Systems
- 8501 Single Burner Boiler Operation
- 8502 Furnace Explosions/Implosions in Multiple Boilers
- 8503 Pulverized Fuel Systems
- 8504 Atmospheric Fluidized-Bed Boiler Operation
- 8505 Stoker Operation
- 8506 Heat Recovery Steam Generators



National Fire Protection Association

1 Batterymarch Park, PO Box 9101, Quincy, MA 02269-9101

To Order Products, Call Toll-Free: 1-800-344-3555