

NFPA®

275

Standard Method of
Fire Tests for the Evaluation
of Thermal Barriers

2022



IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NFPA® codes, standards, recommended practices, and guides (“NFPA Standards”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

REMINDER: UPDATING OF NFPA STANDARDS

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the “Codes & Standards” section at www.nfpa.org.

ADDITIONAL IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

Updating of NFPA Standards

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the “Codes & Standards” section at www.nfpa.org.

Interpretations of NFPA Standards

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: stds_admin@nfpa.org.

For more information about NFPA, visit the NFPA website at www.nfpa.org. All NFPA codes and standards can be viewed at no cost at www.nfpa.org/docinfo.

Copyright © 2021 National Fire Protection Association®. All Rights Reserved.

NFPA® 275

Standard

Method of Fire Tests for the Evaluation of Thermal Barriers

2022 Edition

This edition of NFPA 275, *Standard Method of Fire Tests for the Evaluation of Thermal Barriers*, was prepared by the Technical Committee on Fire Tests. It was issued by the Standards Council on October 2, 2021, with an effective date of October 22, 2021, and supersedes all previous editions.

This edition of NFPA 275 was approved as an American National Standard on October 22, 2021.

Origin and Development of NFPA 275

The 2009 edition was the first edition of NFPA 275, *Standard Method of Fire Tests for the Evaluation of Thermal Barriers Used Over Foam Plastic Insulation*. Several NFPA codes and standards, as well as other model codes, include provisions that require portions of buildings to be separated by 15-minute thermal barriers. Building and fire regulations historically have addressed thermal barriers in vague and imprecise terms. Provisions of other codes and standards indicate that thermal barriers are intended to limit thermal transmission based on fire resistance testing and must remain in place based on a full-scale test. The NFPA 275 fire test methods identified specific sample construction, fire exposures, and acceptance criteria to qualify a material or product for use as a thermal barrier. It was anticipated that this test method would be referenced by other model building and fire codes and standards.

The 2013 edition was revised to address both foam plastic insulation and metal composite materials (MCM). References were updated to reflect the most recent editions.

The 2017 edition was a reconfirmation of the 2013 edition with minor editorial changes and reference updates.

The 2022 edition has revised the test methods for thermal barriers and foam plastic insulation or metal composite material (MCM).

Technical Committee on Fire Tests

Barry L. Badders, Jr., Chair
Intertek Testing Services, TX [RT]

Benjamin H. Caldwell, Bjarke Ingels Group (BIG), NY [SE]
Karen C. Carpenter, Southwest Research Institute, TX [RT]
Soph R. Davenberry, National Energy Management Institute Committee (NEMIC), VA [L]
Rick D. Davis, National Institute of Standards & Technology (NIST), MD [RT]
Scott E. Dillon, Crane Engineering, MN [SE]
William E. Fitch, Phyrefish.com, FL [SE]
Richard G. Gann, Gaithersburg, MD [SE]
Marcelo M. Hirschler, GBH International, CA [SE]
Paul A. Hough, Armstrong World Industries, Inc., PA [M]
William E. Koffel, Koffel Associates, Inc., MD [SE]
Sergei V. Levchik, Israel Chemicals Ltd. (ICL-IP), NY [M]
 Rep. ACC-North American Flame Retardant Alliance
Michael E. Luna, ICC NTA, LLC., TX [RT]
James Andrew Lynch, The Fire Solutions Group, PA [SE]
John Martell, Professional Fire Fighters of Maine/IAFF, ME [L]
 Rep. International Association of Fire Fighters

Rodney A. McPhee, Canadian Wood Council, Canada [M]
Kathleen A. Newman, Firetect, CA [M]
Nicholas Ozog, Wiss, Janney, Elstner Associates, Inc., IL [SE]
Arthur J. Parker, JENSEN HUGHES, MD [SE]
Bill Perdue, American Home Furnishings Alliance -AHFA, NC [U]
Shamim Rashid-Sumar, National Ready Mixed Concrete Assn., NY [M]
Michael L. Savage, Sr., Marion County Building Safety, FL [E]
Michael Schmeida, Gypsum Association, OH [M]
David T. Sheppard, US Bureau of Alcohol, Tobacco, Firearms & Explosives, MD [RT]
Dwayne Sloan, UL LLC, NC [RT]
Kuma Sumathipala, American Wood Council, VA [M]
Robert J. Wills, American Iron and Steel Institute, AL [M]
Peter J. Willse, AXA XL/Global Asset Protection Services, LLC, CT [I]
Dong Zeng, FM Global, MA [I]
 Rep. FM Global

Alternates

Marc Alam, Canadian Wood Council, Canada [M]
 (Alt. to Rodney A. McPhee)
Richard J. Davis, FM Global, MA [I]
 (Alt. to Dong Zeng)
Timothy Earl, GBH International, MI [SE]
 (Alt. to Marcelo M. Hirschler)
Stephen Paul Fuss, US Bureau of Alcohol, Tobacco, Firearms & Explosives, MD [RT]
 (Alt. to David T. Sheppard)
Justin A. Geiman, Fire and Risk Alliance LLC, MD [SE]
 (Alt. to James Andrew Lynch)
Karl Dana Houser, Intertek, PA [RT]
 (Alt. to Barry L. Badders, Jr.)
Jonathan Humble, American Iron and Steel Institute, CT [M]
 (Alt. to Robert J. Wills)

Marc L. Janssens, Southwest Research Institute, TX [RT]
 (Alt. to Karen C. Carpenter)
Elizabeth C. Keller, Engineering Systems, Inc., NC [SE]
 (Alt. to Scott E. Dillon)
Cori Leffler, Firetect, CA [M]
 (Alt. to Kathleen A. Newman)
Daniel A. Martin, JENSEN HUGHES, MD [SE]
 (Alt. to Arthur J. Parker)
Jason V. Smart, American Wood Council (AWC), VA [M]
 (Alt. to Kuma Sumathipala)
Matthew T. Vinci, International Association of Fire Fighters, DC [L]
 (Alt. to John Martell)
Luke C. Woods, UL LLC, MA [RT]
 (Alt. to Dwayne Sloan)

Nonvoting

Robert H. Barker, American Fiber Manufacturers Association, VA [M]
Rohit “Rik” Khanna, US Consumer Product Safety Commission (CPSC), MD [C]
 Rep. US Consumer Product Safety Commission

Andrew Lock, US Consumer Product Safety Commission, MD [C]
 Rep. US Consumer Product Safety Commission

Tracy L. Vecchiarelli, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on fire testing procedures, for reviewing existing fire test standards and recommending appropriate action to NFPA, for recommending the application of and advising on the interpretation of acceptable test standards for fire problems of concern to NFPA technical committees and members, and for acting in a liaison capacity between NFPA and the committees of other organizations writing fire test standards. This Committee does not cover fire tests that are used to evaluate extinguishing agents, devices, or systems.

Contents

Chapter 1 Administration	275- 4	4.3 Test Specimen Instrumentation.	275- 6
1.1 Scope.	275- 4	4.4 Test Specimen Conditioning.	275- 6
1.2 Purpose.	275- 4	4.5 Test Furnace.	275- 6
1.3 Application.	275- 4	4.6 Control of Fire Test.	275- 6
Chapter 2 Referenced Publications	275- 4	4.7 Duration of Fire Test.	275- 7
2.1 General.	275- 4	4.8 Conditions of Acceptance.	275- 7
2.2 NFPA Publications.	275- 4	Chapter 5 Integrity Fire Test (Part II)	275- 7
2.3 Other Publications.	275- 4	5.1 Test Method.	275- 7
2.4 References for Extracts in Mandatory Sections.	275- 5	5.2 Conditions of Acceptance.	275- 7
Chapter 3 Definitions	275- 5	Chapter 6 Test Report	275- 7
3.1 General.	275- 5	6.1 Test Report.	275- 7
3.2 NFPA Official Definitions.	275- 5	Annex A Explanatory Material	275- 8
3.3 General Definitions.	275- 5	Annex B Informational References	275- 8
Chapter 4 Temperature Transmission Fire Test (Part I)	275- 5	Index	275- 9
4.1 Thermal Barrier Supporting Structure.	275- 5		
4.2 Thermal Barrier Test Specimen.	275- 5		

NFPA 275

Standard

Method of Fire Tests for the Evaluation of Thermal Barriers

2022 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Standards." They can also be viewed at www.nfpa.org/disclaimers or obtained on request from NFPA.

UPDATES, ALERTS, AND FUTURE EDITIONS: New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes® Subscription Service or the "List of NFPA Codes & Standards" at www.nfpa.org/docinfo. In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced and extracted publications can be found in Chapter 2 and Annex B.

Chapter 1 Administration

1.1 Scope.

1.1.1* This method of fire tests for qualifying a thermal barrier for protecting foam plastic insulation or metal composite materials (MCM), herein referred to as a *thermal barrier*, is applicable to building construction materials, products, or assemblies intended to be used to protect foam plastic insulation or MCM from direct fire exposure.

1.1.2 The performance of the thermal barrier is evaluated by its ability to limit the temperature rise on its unexposed surface and by the ability of the thermal barrier to remain intact in order to provide protection from ignition of the foam plastic insulation or MCM during a standard fire exposure.

1.1.3 This method of fire tests does not evaluate thermal barriers used in or on upholstered furniture or mattresses.

1.1.4 This standard does not purport to address all safety problems or considerations associated with its use.

1.2 Purpose.

1.2.1 The purpose of this method of fire tests is to evaluate the ability of the thermal barrier to prevent ignition of foam plastic insulation or MCM from a standard fire exposure for a period of 15 minutes.

1.2.2 The purpose of this method of fire tests is also to evaluate the ability of the thermal barrier to remain in place and prevent ignition of foam plastic insulation or MCM for a period of 15 minutes during a standard room/corner fire exposure.

1.3 Application. Two fire tests are conducted to determine the fire performance of the thermal barrier: Part I, temperature transmission fire test, and Part II, integrity fire test.

1.3.1 Part I measures the temperature rise on the unexposed face of the thermal barrier, without foam plastic in place, when it is subjected to a standard fire exposure specified in ASTM E119, *Standard Test Methods for Fire Tests of Building Construction and Materials*, or UL 263, *Fire Tests of Building Construction and Materials*. This Part I test shall be conducted on the thermal barrier only, without the foam plastic in place, to determine the heat-blocking ability of the thermal barrier.

1.3.2 Part II evaluates the ability of the thermal barrier to remain intact in order to provide protection from ignition of the foam plastic insulation or MCM by conducting a test of the thermal barrier and foam plastic insulation or MCM assembly in accordance with a standard room/corner fire test method.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, 2019 edition.

2.3 Other Publications.

2.3.1 ASTM Publications. ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM E119, *Standard Test Methods for Fire Tests of Building Construction and Materials*, 2020.

2.3.2 FM Publications. FM Global, 270 Central Avenue, P.O. Box 7500, Johnston, RI 02919.

ANSI FM 4880, *American National Standard for Evaluating the Fire Performance of Insulated Building Panel Assemblies and Interior Finish Materials*, 2017.

2.3.3 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

UL 263, *Fire Tests of Building Construction and Materials*, 2011, revised 2020.

UL 1715, *Fire Test of Interior Finish Material*, 1997, revised 2017.

2.3.4 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections.

NFPA 5000®, *Building Construction and Safety Code*®, 2021 edition.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1 Shall. Indicates a mandatory requirement.

3.2.2 Should. Indicates a recommendation or that which is advised but not required.

3.2.3 Standard. An NFPA standard, the main text of which contains only mandatory provisions using the word "shall" to indicate requirements and that is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational note, or other means as permitted in the NFPA manuals of style. When used in a generic sense, such as in the phrases "standards development process" or "standards development activities," the term "standards" includes all NFPA standards, including codes, standards, recommended practices, and guides.

3.3 General Definitions.

3.3.1 Foam Plastic Insulation. A cellular plastic, used for thermal insulating or acoustical applications, having a density of 20 lb/ft³ (320 kg/m³) or less, containing open or closed cells, and formed by a foaming agent. [5000, 2021]

3.3.2 Metal Composite Material (MCM). A factory-manufactured panel consisting of metal skins bonded to both faces of a core made of any plastic other than foam plastic as defined in 3.3.1. [5000, 2021]

3.3.3 Thermal Barrier. A material, product, or assembly that prevents or delays ignition of an unexposed surface by limiting the temperature rise and by acting as a flame exposure barrier for a 15-minute time period.

Chapter 4 Temperature Transmission Fire Test (Part I)

4.1 Thermal Barrier Supporting Structure. The thermal barrier supporting structure shall be constructed as a wood stud frame and calcium-silicate board sandwich having minimum dimensions of 36 in. × 36 in. (915 mm × 915 mm).

4.1.1 The supporting structure shall be framed by nominal 2 in. × 4 in. (38 mm × 89 mm) wood studs.

4.1.1.1 The wood studs shall be oriented with the nominal 4 in. (89 mm) side vertical.

4.1.1.2 One additional wood stud shall be positioned in the center of the wood stud framing, parallel to two opposite sides.


4.1.1.3 Each wood stud connection point shall be secured using two evenly spaced 10d nails driven into the ends of the studs.

4.1.2 A single layer of nominal ½ in. (13 mm) thick nominal 46 lb/ft³ (736 kg/m³) density calcium-silicate board shall be installed on both faces of the supporting structure.

4.1.3 Each calcium-silicate board shall be secured to each wood stud of the supporting structure using nominal 1¼ in. (32 mm) long drywall screws, spaced a maximum of 9 in. (229 mm) on center around the perimeter and in the field of the board.

4.1.4 The wood stud and calcium-silicate board test specimen supporting structure shall be constructed as shown in Figure 4.1.4.

4.2 Thermal Barrier Test Specimen. The thermal barrier test specimen shall consist of the thermal barrier supporting structure with the thermal barrier installed on one side.



● Thermocouple

FIGURE 4.1.4 Thermal Barrier Supporting Structure.

4.2.1 The side of the test specimen with the installed thermal barrier shall be designated as the exposed face.

4.2.2 The thermal barrier and the method of securing the thermal barrier shall be representative of the construction for which the thermal barrier is being evaluated.

4.2.3 If joints are a component of the thermal barrier installation in actual use, a minimum of one representative joint shall be incorporated into the thermal barrier.

4.2.4 The joint described in 4.2.3 shall be located in the centerline of the test specimen.

4.3 Test Specimen Instrumentation.

4.3.1 The temperature at the interface of the thermal barrier and the calcium-silicate board shall be measured by a minimum of nine thermocouples.

4.3.2 The thermocouples shall be symmetrically distributed across the surface of the exposed face of the calcium-silicate board as shown in Figure 4.1.4.

4.3.3 The wire leads of each thermocouple shall be in the plane of the interface of the thermal barrier and the exposed face of the calcium-silicate board for a length of not less than 1.5 in. (38 mm).

4.3.4 The thermocouples shall be Type K, with wire leads not greater than 20 AWG [0.032 in. (0.81 mm)] in diameter.

4.3.5 The temperatures measured by the thermocouples shall be measured and recorded at intervals not exceeding 15 seconds.

4.4 Test Specimen Conditioning.

4.4.1 Before the fire test is conducted, the test specimen shall be conditioned to a constant weight at a temperature of 70°F ± 5°F (21°C ± 3°C) and at a relative humidity of 50 percent ± 5 percent.

4.4.2 Constant weight as specified in 4.4.1 shall be considered to have been reached when two successive weighing operations, carried out at an interval of 24 hours, differ by not more than 1 percent.

4.4.3 The test shall be started within 30 minutes of removal of the test specimen from the conditioning area.

4.5 Test Furnace.

4.5.1 The test furnace shall be constructed so as to expose the test specimen in a horizontal configuration mounted on top of the furnace.

4.5.2 The side of the test specimen with the thermal barrier installed shall be exposed to the fire.

4.5.3 The test furnace shall be gas fired and shall be capable of generating and containing a fire exposure controlled to the time-temperature curve as specified in ASTM E119, *Standard Test Methods for Fire Tests of Building Construction and Materials*, or UL 263, *Fire Tests of Building Construction and Materials*, for a period of 15 minutes.

4.5.4 The furnace shall be designed to expose a minimum of a 31.5 in. × 31.5 in. (800 mm × 800 mm) portion of the test specimen.

4.6 Control of Fire Test.

4.6.1 Time-Temperature Curve.

4.6.1.1 The conduct of the fire test shall be controlled by the standard time-temperature curve in accordance with Table 4.6.1.1 for a period of 15 minutes.

4.6.1.2 The temperature inside the furnace shall be within the range of 50°F to 90°F (10°C to 32°C) at the start of the fire test.

4.6.2 Furnace Temperatures. The temperatures in the furnace as determined by the time-temperature curve shall be the average temperature measured by not fewer than three furnace thermocouples.

4.6.2.1 The furnace thermocouples shall be uniformly distributed in a horizontal plane located 12 in. ± ½ in. (305 mm ± 13 mm) below the test specimen's exposed face.

4.6.2.2 The furnace thermocouples shall be as described in ASTM E119, *Standard Test Methods for Fire Tests of Building Construction and Materials*, or UL 263, *Fire Tests of Building Construction and Materials*.

4.6.2.3 The minimum length of the thermocouple wire lead exposed within the furnace shall be not less than 12 in. (305 mm).

4.6.3 Accuracy of Furnace Control. The area under the time-temperature curve, obtained by averaging the results from the thermocouple readings, shall be within 10 percent of the corresponding area under the standard time-temperature curve specified in 4.6.1.1.

4.6.4 Furnace Pressure. The pressure differential between the exposed face of the test specimen and the laboratory test area shall be measured and controlled in accordance with 4.6.4.1 through 4.6.4.9.

4.6.4.1 The pressure-sensing probes shall be as shown in Figure 4.6.4.1.

4.6.4.2 The pressure shall be measured by not fewer than two pressure-sensing probes using a differential pressure instrument capable of being read in graduated increments no greater than 0.01 in. wg (2.5 Pa), with a precision of not more than ±0.005 in. wg (±1.25 Pa).

4.6.4.3 The differential pressure measurement instruments shall be located to minimize stack effects caused by vertical runs of pressure tubing between the pressure-sensing probes and the differential pressure measurement instrument locations.

4.6.4.4 Control of the furnace pressure shall be established beginning no later than 5 minutes after the start of the test and shall be maintained throughout the remainder of the fire test period.

Table 4.6.1.1 Time-Temperature Curve

Time (minutes)	Temperature	
	°F	°C
0	68	20
5	1000	538
10	1300	704
15	1399	760




FIGURE 4.6.4.1 Furnace Pressure-Sensing Probe.

4.6.4.5 The furnace pressure shall be measured and recorded throughout the fire test at intervals not exceeding 1 minute.

4.6.4.6* The pressure shall be reported as the average of each consecutive 3-minute period at 1-minute intervals, starting at 3 minutes after the start of the fire test.

4.6.4.7 The pressure-sensing probes shall be located along the longitudinal centerline of the furnace and shall be 12 in. \pm 1/2 in. (305 mm \pm 13 mm) below the exposed surface of the test specimen.

4.6.4.8 The tips of the probes shall protrude into the furnace a minimum of 3 in. (76 mm) from the interior surface of a furnace wall.

4.6.4.9 During the fire test, the neutral pressure plane in the furnace shall be established below the exposed face of the test specimen such that a positive pressure exists over the entire exposed face of the test specimen after the first 5 minutes of the fire test.

4.7 Duration of Fire Test. The fire test shall be conducted for a period of 15 minutes or until the thermal barrier falls away from the thermal barrier supporting structure or disintegrates, whichever occurs first.

4.8 Conditions of Acceptance.

4.8.1 During the 15-minute test period, the average measured temperature rise above the average temperature at the start of the fire test for the thermocouples described in Section 4.3 shall not exceed 250°F (139°C), and the measured temperature rise of any such single thermocouple shall not exceed 325°F (181°C).

4.8.2 If the average temperature rise or the temperature rise of a single thermocouple exceeds the limits specified in 4.8.1 during the test period, the time of occurrence shall be reported.

Chapter 5 Integrity Fire Test (Part II)

5.1* Test Method. The thermal barrier and foam plastic insulation or MCM shall be tested in accordance with NFPA 286; the room fire test in ANSI FM 4880, *American National Standard for Evaluating the Fire Performance of Insulated Building Panel Assemblies and Interior Finish Materials*; or UL 1715, *Fire Test of Interior Finish Material*.

5.1.1 The specific type of foam plastic insulation or MCM to be protected by the thermal barrier shall be installed on a substrate and shall form the interior surface of the test walls and ceiling.

5.1.2 The thermal barrier shall be installed over the interior face of the foam plastic insulation or MCM in the manner for which recognition is desired.

5.1.3 The foam plastic insulation or MCM shall be tested at the maximum thickness intended for use.

5.1.4 The assemblage of foam plastic insulation or MCM and applied thermal barrier described in 5.1.2 shall be considered the test assembly.

5.2 Conditions of Acceptance.

5.2.1 The conditions of acceptance for fire tests conducted in accordance with ANSI FM 4880, *American National Standard for Evaluating the Fire Performance of Insulated Building Panel Assemblies and Interior Finish Materials*; or UL 1715, *Fire Test of Interior Finish Material*; shall be as specified in the fire test standard used.

5.2.2 For fire tests conducted using NFPA 286, the conditions of acceptance shall be as specified in 5.2.2.1 through 5.2.2.4.

5.2.2.1 During the 40 kW fire exposure portion of the test, flames shall not spread to the ceiling.

5.2.2.2 During the 160 kW fire exposure portion of the test, the test assembly shall comply with 5.2.2.2.1 through 5.2.2.2.4.

5.2.2.2.1 Flames shall not spread to the outer extremity of the test assembly on any wall or ceiling.

5.2.2.2.2 Flashover, as defined by NFPA 286, shall not occur.

5.2.2.2.3 The peak rate of heat release throughout the NFPA 286 test shall not exceed 800 kW.

5.2.2.2.4 The total smoke released throughout the NFPA 286 test shall not exceed 10,764 ft² (1000 m²).

Chapter 6 Test Report

6.1 Test Report. A test report shall include the following information at a minimum:

- (1) Name of the testing laboratory and the test date
- (2) Names of the sponsor or customer, the manufacturer, and the material, product, or assembly tested
- (3) Documentation of how and when the test specimen and test assembly were prepared and details of the application of the thermal barrier for both fire test methods (Parts I and II)
- (4) Temperature readings of the furnace thermocouples and a comparison to the standard time-temperature curve

- (5) Temperature readings of the thermocouples described in Section 4.3
- (6) Pressure measurements in the furnace during the Part I test
- (7) Statement as to whether the thermal barrier met the conditions of acceptance in the Part I test
- (8) Density, thickness, and type of foam plastic insulation or MCM used in the Part II test
- (9) The information required to be reported as specified in the fire test used in the Part II test
- (10) Statement as to whether the thermal barrier met the conditions of acceptance in the Part II test
- (11) Observations made during both fire tests (Parts I and II) by the laboratory personnel conducting the tests and the times at which such observations were made
- (12) Statement as to whether the proposed thermal barrier material, product, or assembly met the conditions of acceptance in both the Part I and Part II tests

Annex A Explanatory Material

Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.

A.1.1.1 Model building codes require foam plastic insulation and, in some installations, metal composite material (MCM), to be covered by a thermal barrier, or separated from the interior of the building by, a thermal barrier to reduce the possibility of ignition or delay its occurrence. The typical time specified is 15 minutes based on a fire exposure similar to that in ASTM E119, *Standard Test Methods for Fire Tests of Building Construction and Materials*, or UL 263, *Fire Tests of Building Construction and Materials*. The fire exposure conditions in these test methods are similar.

A.4.6.4.6 This is equivalent to a 3-minute running average.

A.5.1 The 2009, 2013, and 2017 editions of NFPA 275 included UL 1040, *Fire Test of Insulated Wall Construction*, and the 25 ft (7.6 m) and the 50 ft (15.2 m) high corner tests of ANSI FM 4880, *American National Standard for Evaluating the Fire Performance of Insulated Building Panel Assemblies and Interior Finish Materials*. NFPA technical committee members have been made aware that those tests have not been conducted for many years. However, approvals of any materials or products associated with these fire tests contained in any earlier editions of NFPA 275 are considered valid and should remain so. The 16 ft (4.9 m) parallel panel test contained in the newer edition of

ANSI FM 4880 has not yet been evaluated for use as an integrity fire test for thermal barriers. The room fire test in ANSI FM 4880 is the only test from that standard being retained as an option.

Annex B Informational References

B.1 Referenced Publications. The documents or portions thereof listed in this annex are referenced within the informational sections of this standard and are not part of the requirements of this document unless also listed in Chapter 2 for other reasons.

B.1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 275, *Standard Method of Fire Tests for the Evaluation of Thermal Barriers Used over Foam Plastic Insulation*, 2009 edition.

NFPA 275, *Standard Method of Fire Tests for the Evaluation of Thermal Barriers*, 2013 edition.

NFPA 275, *Standard Method of Fire Tests for the Evaluation of Thermal Barriers*, 2017 edition.

B.1.2 Other Publications.

B.1.2.1 ASTM Publications. ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM E119, *Standard Test Methods for Fire Tests of Building Construction and Materials*, 2020.

B.1.2.2 FM Publications. FM Global, 270 Central Avenue, P.O. Box 7500, Johnston, RI 02919.

ANSI FM 4880, *American National Standard for Evaluating the Fire Performance of Insulated Building Panel Assemblies and Interior Finish Materials*, 2017.

B.1.2.3 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

UL 263, *Fire Tests of Building Construction and Materials*, 2011, revised 2020.

UL 1040, *Fire Test of Insulated Wall Construction*, 1996, revised 2017.

B.2 Informational References. (Reserved)

B.3 References for Extracts in Informational Sections. (Reserved)

Index

Copyright © 2021 National Fire Protection Association. All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document that it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of NFPA.

<p>-A-</p> <p>Administration, Chap. 1</p> <p> Application, 1.3</p> <p> Purpose, 1.2</p> <p> Scope, 1.1</p>	<p>-S-</p> <p>Shall</p> <p> Definition, 3.2.1</p> <p>Should</p> <p> Definition, 3.2.2</p> <p>Standard</p> <p> Definition, 3.2.3</p>
<p>-D-</p> <p>Definitions, Chap. 3</p>	<p>-T-</p> <p>Temperature Transmission Fire Test (Part I), Chap. 4</p> <p> Conditions of Acceptance, 4.8</p> <p> Control of Fire Test, 4.6</p> <p> Accuracy of Furnace Control, 4.6.3</p> <p> Furnace Pressure, 4.6.4</p> <p> Furnace Temperatures, 4.6.2</p> <p> Time-Temperature Curve, 4.6.1</p> <p> Duration of Fire Test, 4.7</p> <p> Test Furnace, 4.5</p> <p> Test Specimen Conditioning, 4.4</p> <p> Test Specimen Instrumentation, 4.3</p> <p> Thermal Barrier Supporting Structure, 4.1</p> <p> Thermal Barrier Test Specimen, 4.2</p> <p>Test Report, Chap. 6</p> <p> Test Report, 6.1</p> <p>Thermal Barrier</p> <p> Definition, 3.3.3</p>
<p>-E-</p> <p>Explanatory Material, Annex A</p>	
<p>-F-</p> <p>Foam Plastic Insulation</p> <p> Definition, 3.3.1</p>	
<p>-I-</p> <p>Informational References, Annex B</p> <p>Integrity Fire Test (Part II), Chap. 5</p> <p> Conditions of Acceptance, 5.2</p> <p> Test Method, 5.1, A.5.1</p>	
<p>-M-</p> <p>Metal Composite Material (MCM)</p> <p> Definition, 3.3.2</p>	
<p>-R-</p> <p>Referenced Publications, Chap. 2</p>	