

NFPA 328
Manholes, Sewers,
and Similar
Underground
Structures
1992 Edition



NOTICE

All questions or other communications relating to this document should be sent only to NFPA headquarters, addressed to the attention of the Committee responsible for the document.

For information on the procedures for requesting Technical Committees to issue Formal Interpretations, proposing Tentative Interim Amendments, proposing amendments for Committee consideration, and appeals on matters relating to the content of the document, write to the Secretary, Standards Council, National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

A statement, written or oral, that is not processed in accordance with Section 5 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Users of this document should consult applicable federal, state and local laws and regulations. NFPA does not, by the publication of this document, intend to urge action that is not in compliance with applicable laws, and this document may not be construed as doing so.

Policy Adopted by NFPA Board of Directors on December 3, 1982

The Board of Directors reaffirms that the National Fire Protection Association recognizes that the toxicity of the products of combustion is an important factor in the loss of life from fire. NFPA has dealt with that subject in its technical committee documents for many years.

There is a concern that the growing use of synthetic materials may produce more or additional toxic products of combustion in a fire environment. The Board has, therefore, asked all NFPA technical committees to review the documents for which they are responsible to be sure that the documents respond to this current concern. To assist the committees in meeting this request, the Board has appointed an advisory committee to provide specific guidance to the technical committees on questions relating to assessing the hazards of the products of combustion.

Licensing Provision—This document is copyrighted by the National Fire Protection Association (NFPA).

1. Adoption by Reference—Public authorities and others are urged to reference this document in laws, ordinances, regulations, administrative orders, or similar instruments. Any deletions, additions, and changes desired by the adopting authority must be noted separately. Those using this method are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. The term "adoption by reference" means the citing of title and publishing information only.

2. Adoption by Transcription—A. Public authorities with lawmaking or rule-making powers only, upon written notice to the NFPA (Attention: Secretary, Standards Council), will be granted a royalty-free license to print and republish this document in whole or in part, with changes and additions, if any, noted separately, in laws, ordinances, regulations, administrative orders, or similar instruments having the force of law, provided that: (1) due notice of NFPA's copyright is contained in each law and in each copy thereof; and (2) that such printing and republication is limited to numbers sufficient to satisfy the jurisdiction's lawmaking or rule-making process. B. Once this NFPA Code or Standard has been adopted into law, all printings of this document by public authorities with lawmaking or rule-making powers or any other persons desiring to reproduce this document or its contents as adopted by the jurisdiction in whole or in part, in any form, upon written request to NFPA (Attention: Secretary, Standards Council), will be granted a nonexclusive license to print, republish, and vend this document in whole or in part, with changes and additions, if any, noted separately, provided that due notice of NFPA's copyright is contained in each copy. Such license shall be granted only upon agreement to pay NFPA a royalty. This royalty is required to provide funds for the research and development necessary to continue the work of NFPA and its volunteers in continually updating and revising NFPA standards. Under certain circumstances, public authorities with lawmaking or rule-making powers may apply for and may receive a special royalty where the public interest will be served thereby.

3. Scope of License Grant—The terms and conditions set forth above do not extend to the index to this document.

(For further explanation, see the Policy Concerning the Adoption, Printing, and Publication of NFPA Documents, which is available upon request from the NFPA.)

Statement on NFPA Procedures

This material has been developed under the published procedures of the National Fire Protection Association, which are designed to assure the appointment of technically competent Committees having balanced representation. While these procedures assure the highest degree of care, neither the National Fire Protection Association, its members, nor those participating in its activities accept any liability resulting from compliance or noncompliance with the provisions given herein, for any restrictions imposed on materials or processes, or for the completeness of the text.

NFPA has no power or authority to police or enforce compliance with the contents of this document, and any certification of products stating compliance with requirements of this document is made at the peril of the certifier.

Copyright © 1992 NFPA, All Rights Reserved

NFPA 328

Recommended Practice for the Control of Flammable and Combustible Liquids and Gases in Manholes, Sewers, and Similar Underground Structures 1992 Edition

This edition of NFPA 328, *Recommended Practice for the Control of Flammable and Combustible Liquids and Gases in Manholes, Sewers, and Similar Underground Structures*, was prepared by the Technical Committee on Tank Leakage and Repair Safeguards, released by the Correlating Committee on Flammable Liquids, and acted on by the National Fire Protection Association, Inc. at its Annual Meeting held May 18-21, 1992, in New Orleans, LA. It was issued by the Standards Council on July 17, 1992, with an effective date of August 14, 1992, and supersedes all previous editions.

The 1992 edition of this document has been approved by the American National Standards Institute.

Changes other than editorial are indicated by a vertical rule in the margin of the pages on which they appear. These lines are included as an aid to the user in identifying changes from the previous edition.

Origin and Development of NFPA 328

Sufficient case histories of fires and explosions in underground structures fully justify a careful review of the material contained within this recommended practice. The sources of flammable vapor-air mixtures in these locations, coupled with a study of unsafe practices and protective practices contained herein, certainly will indicate the desirability of utilizing the applicable corrective measures suggested in the summary of this report. This recommended practice was first adopted in 1956, and subsequent editions were published in 1964, 1970, 1975, 1982, 1987, and 1992.

Minor amendments were made to Sections 2-4, 2-4.4, and 2-6 in this 1992 edition.

Correlating Committee on Flammable Liquids

Leon C. Schaller, *Chairman*

E. I. du Pont de Nemours & Company, DE

Robert P. Benedetti, *Secretary*

National Fire Protection Association, MA
(Nonvoting)

John J. Hawley, Underwriters Laboratories Inc., IL

Donald M. Johnson, San Bruno, CA

C. L. Kingsbaker, Atlanta, GA

Steven Landon, Trophy Club, TX

Eugene S. Schmitt, Dept. of State Police, MI

Orville M. Slye, Loss Control Associates Inc., PA

W. J. Smith, Underwriters Laboratories Inc., IL

Nonvoting

Paul C. Lamb, Englewood, NJ

(Member Emeritus)

Technical Committee on Tank Leakage and Repair Safeguards

John J. Hawley, *Chairman*

Underwriters Laboratories Inc., IL

William C. Conklin, WCC Tank Technology, Inc., NY

Donald W. Fleischer, Veeder-Root Co., CT

Wayne Geyer, Steel Tank Institute, IL

Mark I. Grossman, Reliance National Risk Specialists, NY

Carl V. Hasselback, White Arrow Service Stations Inc., NY
Rep. Petroleum Marketers Assn. of America

Donald M. Johnson, San Bruno, CA

Rep. Western States Petroleum Assn.

Kenneth D. Lattimer, Star Enterprise (Texaco), GA

Rep. NFPA Industrial Fire Protection Section

George S. Lomax, Heath Consultants Inc., PA

Paul I. Meli, Bridgeport Chemical Corp., FL

Michael Nimocks, State of Ohio Fire Marshal's Office, OH

Henry L. Politi, Tanknology Corp. Int., FL

Rep. Leak Detection Technology Assn.

Vernon Ray, State Fire Marshal's Office, TX

Frank P. Reisenauer, F K Fire Safety Consultants, WI

Robert N. Renkes, Petroleum Equipment Institute, OK

Joyce A. Rizzo, Lexicon Environmental Assn., Inc., PA

Howard Robbins, Joor Manufacturing Inc., CA

James R. Rocco, B. P. Oil Co., OH

Rep. American Petroleum Institute

Thomas Schruben, U.S. EPA Washington, DC

Todd G. Schwendeman, Groundwater Technology Inc., NY

Bruce R. Sharp, Armor Shield Inc., OH

Robert P. Siegel, 3M Company, MN

Alternate

Tony Rieck, Armor Shield Inc., OH

(Alternate to B. R. Sharp)

Robert P. Benedetti, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the text of this edition. Since that time, changes in the membership may have occurred.

NOTE: Membership on a Committee shall not in and of itself constitute an endorsement of the Association or any document developed by the Committee on which the member serves.

Contents

Foreword	328- 5
Chapter 1 The Problem	328- 5
1-1 General	328- 5
1-2 Sources of Ignition	328- 5
1-3 Sources of Flammable and Combustible Liquids and Gases	328- 5
1-4 Damage to Underground Lines	328- 6
1-5 Unsafe Practices	328- 7
Chapter 2 Protective Practices	328- 7
Chapter 3 Summary	328- 8
Chapter 4 Referenced Publications	328- 9
Appendix A	328-10
Index	328-11

NFPA 328**Recommended Practice for the Control of
Flammable and Combustible Liquids and
Gases in Manholes, Sewers, and Similar
Underground Structures****1992 Edition**

NOTICE: Information on referenced publications can be found in Chapter 4.

Foreword

Manholes, sewers, and similar underground conduits have long been recognized as constituting areas where fire and explosion hazards of some severity might exist. The probability of an explosion within an underground space depends on two factors: (1) that the atmosphere contains a mixture of flammable vapor and air within the flammable range, and (2) that there be a coincident source of ignition. The severity of an individual explosion and its consequences depends on various factors. The possibility that any one explosion might result in a major catastrophe is always present.

This publication is limited to the control of hazards presented by flammable and combustible liquids and gases found in manholes, sewers, vaults, and similar underground structures. The underground structures include: sanitary sewers, storm drains, water lines, fuel gas distribution systems, electric light and power conduits, telephone and telegraph communication lines, street-lighting conduits, police and fire signal systems, traffic signal lines, refrigeration service lines, steam lines, and petroleum pipelines.

The term "underground structures" is not intended to include subways, tunnels, and the substructural areas of buildings such as underground garages.

The purpose of this publication is to give to enforcement officials, fire authorities, contractors, and owners of underground structures guidance on problems involving flammable and combustible liquids and gases that might be found in underground structures.

Chapter 1 The Problem

1-1 General. With increasing congestion and for aesthetic considerations, the trend in civic planning is toward the installation of all types of utility services beneath the street surface. This results in a continuous program of excavation and construction, with frequent damage to existing structures.

1-2 Sources of Ignition.

1-2.1 The possibility of ignition of flammable gases or vapors that might collect in underground areas is limited by certain fundamental conditions. The vapor must be mixed with sufficient air to make a flammable mixture or

it must be escaping into air at a point where a flammable mixture can be created. Heat of sufficient intensity to ignite the particular air-vapor mixture involved must be present at the place where a flammable mixture exists. Such heat might be caused by an open flame, an electric arc or spark, an incandescent heated particle, or a hot surface.

1-2.2 The flammable limits of the gases and vapors that have been found in underground structures are listed in Appendix A. Flammable mixtures are formed when the concentration of these gases in air is between the minimum and maximum shown.

1-2.3 Any open flame is a potential source of ignition. These can be encountered in everyday work operations. Little control can be exerted over the casual sources of ignition when flammable vapors are escaping from or into underground structures. Such casual sources of ignition include burners and warning lanterns used by street surface maintenance crews, automotive and other internal combustion engines, tar pots, and pedestrian smokers.

1-2.4 The heat of an electric arc occurring in electric underground structures can cause the distillation of insulating material, thus producing flammable gases that in turn can be ignited by the arc itself when the proper air-gas ratio is reached. This usually will occur when the arc reaches a manhole or vault after having started in a duct. Other gases or flammable vapors, if present, can also be ignited by such an arc.

1-2.5 Static electricity can be a source of ignition and its accumulation is generally greatest in an atmosphere of low humidity. The hazard appears when static accumulates to the extent where a spark discharge occurs. Static electricity can be generated when a liquid under pressure escapes from a pipe at high velocity. Particles of dust, scale, or rust, or liquid droplets, inside the pipe can become heavily charged with static when blown out by gas or vapor and, if they impinge on an electrically isolated body, the body will accumulate the charge and a spark discharge can occur.

1-3 Sources of Flammable and Combustible Liquids and Gases.

1-3.1 The condition created by the existence of gases and vapors in underground structures can be grouped into two classes: (1) flammable and (2) injurious to life. The latter condition results from the toxic or suffocating properties of the gases or vapors. Some of these liquids and gases fall into both classes. While this publication deals primarily with the flammable limits associated with liquids and gases, some of which are listed in Appendix A, additional precautions may be required to protect against health hazards. An example is hydrogen sulfide; its dangerous breathing concentration is only a small fraction of the lower flammable limit (LFL).

1-3.2 Natural Gas. Natural gas is gas originating from naturally occurring gas- or oil-bearing strata. In oil- and natural gas-producing areas, cracks and faults in the underlying strata or abandoned wells may permit gas to permeate the soil and enter underground conduits and vaults. Within the boundaries of some cities, there are actively producing oil and gas fields and many of these underlie developed areas, residential and industrial, where underground structures are now installed.

1-3.3 Fuel Gas. Fuel gases include natural gas, liquefied petroleum gases, coke-oven gas, coal gas, oil gas, carburated water gas, water gas, producer gas, and blast-furnace gas. These gases, except liquefied petroleum gases, have specific gravities lower than that of air so that, when released in an underground space, they will tend to rise and diffuse rather rapidly above the point of leakage. These gases, when mixed with air within certain limits, produce flammable mixtures. Since the oxygen content of each of these gases when not mixed with air is usually below 1.0 percent, they can be classed as suffocating gases. With the exceptions of natural gas and liquefied petroleum gases, they are also highly toxic because of the high carbon monoxide content. Natural gas and other fuel gases, as distributed by utility companies in underground pipes, are also a source of flammable gas. These pipes are subject to damage caused by corrosion, electrolysis, structural failures, and adjacent excavating. These causes are discussed in greater detail in later paragraphs of this section.

1-3.4 Refrigerant Gases. A number of the common refrigerants, such as ammonia, methyl chloride, ethyl chloride, methyl bromide, and ethyl bromide, have varying degrees of flammability. With the exception of ammonia, all of these refrigerants are heavier than air when in the vapor phase. Therefore, if they are released in large quantities in closed spaces, they will flow downward into the lowest areas. Of these, only ammonia has a sufficiently strong odor in dilute concentrations to indicate its presence. Exposure to ammonia vapors can cause severe burns even at concentrations below the flammable limits. Liquid ammonia is often distributed through underground street pipes for refrigeration service in the business districts of many large cities. This system of pipes is subject to the same exposure to physical damage as fuel gas pipes and petroleum pipelines.

1-3.5 Electric Cable and Other Insulating Material Gases. This source of flammable gas is practically limited to severely overloaded electric underground circuits. A breakdown of cable insulation will produce an electric arc. If the protective fuses do not operate promptly, this electric arc will continue. The heat of the arc can, by destructive distillation of cable insulation (varnished cambric, rubber, or paper), produce flammable gases containing hydrogen, carbon monoxide, and hydrocarbons.

1-3.6 Chemicals. Accidental spillage in chemical processing plants and disposal of waste chemical products through sewers by industrial plants are potential sources or contributing causes for explosive conditions. Examples of such products are carbon disulfide and ammonia. Calcium carbide will react with water to produce the flammable gas acetylene.

1-3.7 Sewage Gases. Sewage gas results from the fermentation or decomposition of organic matter. These gases can be produced when organic matter has settled as a solid in sewer lines as a result of flat grades, crevices, sumps, or obstructions where consistent flow of sewage is lacking, or as a result of bacterial action on wood or other organic material immersed in water. These flammable gases are principally methane, hydrogen sulfide, and hydrogen and,

on the basis of present evidence, they seldom reach explosive concentrations in sewers and drains. However, when they are mixed with other flammable liquids and gases present in sewers, explosive conditions might exist.

1-3.8 Flammable and Combustible Liquids. Cleaning solvents and compounds washed down drains by industrial and domestic users can be the source of flammable vapors. Hydrocarbon liquids (for example, gasoline and kerosene at industrial plants, service stations, and garage wash racks) are occasionally sent to sewers and drains either accidentally or through negligence. Any leaking underground tank containing liquids, such as a service station's underground gasoline tanks, can also be a source of flammable vapors in underground structures (see NFPA 329, *Recommended Practice for Handling Underground Leakage of Flammable and Combustible Liquids*).

1-3.9 Petroleum Pipeline Liquids. Liquid petroleum and liquefied petroleum gases are conveyed by pipelines installed beneath public streets and rights-of-way. These pipelines are exposed to the same sources of physical damage as fuel gas pipes, as discussed in detail later. If any of these pipelines should fail, the escaping liquids and gases can penetrate substructure walls or rise to the street surface. Liquids can be washed into drains or enter the ventilating openings in the manhole covers of underground structures. Escaping liquid petroleum products can evaporate in the ground, penetrate the surrounding ground, or enter a confined space to produce a flammable mixture.

1-3.10 Penetration of Structures by Gases. Flammable gas present in the soil can enter conduits, sewers, drains, or basements because underground structures constructed of cement, concrete, brick, or vitreous tile generally are not built to be impervious to gas. If a flammable gas or liquid is present in the soil, as might be produced by decaying organic matter, there is some likelihood that it will penetrate an adjacent underground structure. Particular attention should be paid to landfill sites developed by the depositing of garbage and trash. Gas from this source, primarily methane, might not have an odor. Gas can enter the subsurface sections of buildings through cracks or around any underground conduits that penetrate the substructure walls.

1-3.11 Electric Circuit Oil Switches and Oil-Insulated Transformers. This equipment is frequently installed in a street vault, and electrical failures will occasionally result in an explosion. The action of protective devices in shutting off current is usually very fast, approximately two seconds or less. This has the effect of limiting the damage to the vault in which the failure occurs. However, when the vault is adjacent to or within a large structure, such an explosion can result in heavy damage.

1-4 Damage to Underground Lines.

1-4.1 Corrosion. One type of corrosion affecting gas lines and petroleum pipelines occurs when the soil composition and resistance are such that electric current from the development of local action cells can flow readily from anodic areas on the pipe surface through the soil to the cathodic areas on the same pipe. Such conditions may be

due to the soil's acid or alkali content, organic matter, variations of water or oxygen content, soil type, or the presence of certain bacteria in the soil. Corrosion can also occur as a result of chemical reaction between the pipe and surrounding soil. Corrosion of this type can be controlled with cathodic protection.

1-4.2 Stray Currents. Another cause of corrosion in underground lines is stray electric currents originating from such sources as direct-current electric railways and trolley lines using rails to carry return currents; industrial plant direct-current machinery using the ground as a return conductor; stray currents from cross-connections with other structures carrying current; and leakage from foreign system cathodic protection rectifiers. These currents might not be destructive where they enter the piping system, but drainage of these stray currents to ground can cause corrosion at these points of discharge.

1-4.3 Structural Failures. The allocation of insufficient space for the installation of underground structures can, in some situations, result in the encasement of gas and flammable and combustible liquid pipes in the walls of ducts and subsequently constructed masonry vaults. Such pipes from vaults might be fractured under certain conditions. Flood washouts, earthquakes, and landslides can cause the dislocation and movement of ground and are often responsible for pipe fractures. Rupture of water mains due to corrosion, electrolysis, or structural failure can, in turn, cause washout of soil that supports gas and flammable liquid pipes. Lacking support, these pipes can fracture.

1-4.4 Excavating. Contractors doing excavation work often encounter gas mains and flammable and combustible liquid pipes. Even though aware of their presence, workers might unintentionally damage a pipe, resulting either immediately or ultimately in a leak. Damage such as this is not always reported and often inadequate repairs are attempted by the party responsible for the physical damage.

1-4.5 Fire Damage. Fires in underground structures can result in spalling of concrete, destruction of protective linings, and deterioration of other interior surfaces. Such damage, if extensive, can weaken the structure.

1-5 Unsafe Practices.

1-5.1 Before washing spilled petroleum products from street surfaces into drains or sewers (a potentially dangerous action and often an unlawful practice), other disposal means, such as soaking up the substance with sand, rags, or mops, should be considered. If, in an emergency, no alternative is available, disposal into a drain or sewer should be done only on the decision of a qualified person, after appropriate public authorities have been notified.

1-5.2 Disastrous consequences can result from the thoughtless or deliberate dumping into drains of waste products that are either flammable or that, by reaction with organic matter in sewers, can produce a flammable mixture. Though the presence of a flammable material might be detected, its source can be difficult to determine.

Chapter 2 Protective Practices

2-1 The adoption of protective measures that will detect the presence of flammable materials in manholes and vaults and provide the means to prevent the accumulations of gas or vapor within the explosive range should reduce the incidence of explosions in underground structures. Such a defensive procedure is necessary because of the difficulty of eliminating the flammable material at its source.

2-2 Numerous sources of ignition can be found in underground structures. The operators of underground structures can materially reduce the number of ignitions by eliminating the use of flames in suspected areas. Experience has shown, though, that fire and explosion incidence can best be reduced by the elimination of flammable vapors from the atmosphere of the underground structure. It is all but impossible to remove all ignition sources.

2-3 Considering the diversity of contributing causes for flammable products in underground structures, protective practices should be designed to reduce to a minimum the quantity of flammable vapors. Where such vapors are found to be present, a complete purge of the manhole or vault atmosphere should be made and the source of the flammable vapors eliminated. Manholes and vaults should be ventilated by forced draft when necessary to prevent concentrations of these vapors within the explosive range. After complete ventilation of the underground structure, the atmosphere should be tested with a combustible gas indicator before entering and before any hot work is performed. A low reading on the combustible gas indicator does not necessarily mean that the toxicity hazard has been eliminated. Adequate ventilation should be maintained and periodic gas analysis of the atmosphere during any such work should be made.

2-4 Detection Instruments. There are a number of instruments that can be used to detect unsafe atmospheres found in underground structures. They should be used to determine the characteristics of any questionable situation. Ensure that instruments are properly calibrated before use.

2-4.1 Oxygen. There are indicators that give a direct reading of oxygen concentration. Under no conditions should an area be entered without self-contained breathing apparatus unless it contains at least 19.5 percent oxygen.

2-4.2 Carbon Monoxide. This gas in concentrations greater than 0.10 percent by volume results in unconsciousness in little more than an hour and death in four hours. Further increases in concentration reduce this time element. Its effect is to displace oxygen in the blood stream. Several instruments have been developed for the quick detection of carbon monoxide. Those capable of detecting the smallest concentrations considered hazardous are the carbon monoxide tester (palladium-molybdate complex) and the carbon monoxide indicator.

2-4.3 Hydrogen Sulfide. This flammable and toxic gas is colorless and has an odor resembling rotten eggs. It is toxic in concentrations above 0.002 percent by volume. Continued exposure will paralyze the olfactory nerves. The

hydrogen sulfide detector will detect the low toxic concentrations of this gas.

2-4.4 Fuel Gases and Vapors from Flammable and Combustible Liquids. Combustible gas indicators are available in a number of different types to meet the requirements of the specific use to which they may be applied. The most common type is an "all-purpose" instrument suitable for the detection of flammable gases such as natural gas, manufactured gas, hydrogen, and acetylene and all vapor-air mixtures associated with fuel oils, gasoline (including leaded gasoline), alcohols, and acetone. This instrument indicates the presence of gases and vapors in percent of the lower flammable limit (LFL). It must be calibrated, used, and maintained in accordance with the manufacturer's instructions. This instrument must be calibrated on the specific gas being sampled, i.e., natural or manufactured gas, and has a scale range of zero to 100 percent. A portable combustible gas indicator is also available for operation in explosive atmospheres.

2-4.5 Periodic checks for the presence of flammable vapors using appropriate instruments should be made in all water, gas, and electric underground structures. The frequency of such surveys will depend on the previous experience and the potential hazard.

2-4.6 Liquefied petroleum gases and utility gases are odorized to facilitate detection unless the odorant would serve no useful purpose as a warning agent, but such cases are relatively rare and practically all such gases distributed by underground pipelines are odorized. Experience has shown that odorants can be absorbed when traveling through the soil.

2-5 Volatile flammable liquids can enter a drainage system because of a spill or other emergency. Steps should be taken to minimize the hazard by exhausting the vapors with blowers or exhaust fans driven by explosionproof motors and by pumping out the liquid with pumps equipped with explosionproof motors. Floor drain openings into buildings in the area of the spill and for some distance downstream should be checked for escape of vapors. Water should be placed in any dry traps to seal them. Copious quantities of water should be used to flush any flammable or combustible liquid through the system quickly and to dilute it, if miscible with water.

2-6 Underground tanks of flammable liquids can be a source of leakage. When a tank is found to be leaking, its contents should be removed immediately. When such a tank is taken out of service, abandoned, or removed, the procedures described in Appendix C of NFPA 30, *Flammable and Combustible Liquids Code*, entitled Abandonment or Removal of Underground Tanks, should be followed.

2-7 Sewers and drains should be periodically flushed and cleaned to prevent deposits of organic material and slime growth. Periodic inspections should be made of industrial plants to prevent the discharge into sewers of waste that might produce explosive gases due to physical or chemical impurities, high temperatures, alkalis, or acids, unless the system is specifically designed for such materials.

2-8 Periodic checks of protective equipment in underground electric systems should be made. Efforts should be made to prevent the overloading of cables and to avoid arcing conditions that might form flammable gas by the breakdown of insulation.

Chapter 3 Summary

3-1 A review of all the factors relating to the problem of explosive hazards in underground structures, together with an analysis of causes of explosions, indicates that flammable material might at some time be present in an underground structure.

Control procedures and education are the proper approaches to the problem. Effective control cannot be maintained unless the various utilities involved, the administrative bodies of cities, and others cooperate in an adequate safety program.

3-2 Utility companies should maintain an adequate inspection program for the detection of leaks at street openings. This can best be accomplished by the use of combustible gas indicators, vegetation surveys, and other methods. Periodic inspection and testing of key equipment should be conducted with reasonable frequency as a part of regular maintenance operations. Such a distribution piping maintenance program could be carried out in accordance with the requirements of federal and state pipeline regulations.

3-3 Inactive gas services and mains should be abandoned in accordance with federal and state regulations.

3-4 Automatic or manually operated drains in industrial piping should be designed so as not to discharge their product into underground structures.

3-5 Owners and operators of underground pipelines carrying flammable and combustible liquids should maintain an adequate inspection program for the detection of escaping liquids.

3-6 RP 1621, *Recommended Practice for Bulk Liquid Stock Control at Retail Outlets*, published by the American Petroleum Institute, will be of value to operators of service stations.

3-7 An in-service training program for all employees whose occupation is associated with underground structures will teach them to recognize the presence of fire and toxic hazards and oxygen deficiencies and teach them how to take proper precautions against such possibilities.

3-8 Some public authorities have established a program to control or prevent the discharge into sewers and drains of all products likely to result in flammable atmospheres in vaults and manholes.

3-9 Sewers and drains should be designed to ensure that proper cleansing velocities and proper ventilation are maintained so as to prevent infiltration and to avoid the settling of heavy solids. Sewers and drains should be designed to minimize the danger of settlement and failure that in turn might break other adjacent underground structures.

3-10 Where ventilation of a vault or manhole is necessary and mechanical ventilation cannot be provided, the manhole or vault should be designed (depending on local conditions) so that effective natural ventilation for vapors or gases lighter than air can be obtained. Manholes for sewers should be regularly spaced to provide effective ventilation and explosion relief.

3-11 Every effort should be made to establish standard practice for the design, construction, and maintenance of all underground structures with respect to the elimination of explosive hazards and the contributory causes.

3-12 Close liaison should be established between the fire chief and industrial safety officials. Mutually approved procedures should be developed to cope with emergencies so that fire fighters can act effectively in their line of duty.

3-13 All agencies having underground structures should be prepared to furnish contractors with the record of the locations of such adjacent structures or furnish a person who knows the location of these pipes. In the event the exact location of any underground structure is not known, the contractor should make a physical inspection of the entire right-of-way of the proposed excavation by employing underground detecting devices and visual inspection of adjacent structures.

3-14 Apart from direct damage to piping, contractors should take extra precautions to avoid damage to corrosion protecting coatings, anodes, electrodes, bonding facilities, and related devices. If these are disturbed or damaged, the owner of the structures should be notified before backfilling the excavation. Care should be taken in all excavations in which wire or metal is found, even though these are not immediately adjacent to a pipeline. They may be part of the protective system.

3-15 Public authorities should:

(a) Adopt an ordinance that would require a contractor before starting construction or excavation work (1) to obtain a permit, (2) to notify the owner of adjacent underground structures in writing of his intention to start work, and (3) to obtain from the owner the exact information on the location of the underground structures and pipes containing flammable materials. All agencies having underground structures should be prepared to furnish contractors with exact information on the location of such underground structures. This permit should prohibit the contractor from interference with the above-mentioned pipes without giving prior notice to the owner or operator.

(b) Require anyone conducting blasting operations to obtain a permit. The permit should not be granted until the owners of adjacent underground structures have been consulted. NFPA 495, *Explosive Materials Code*, contains additional information on this subject.

(c) Require anyone razing buildings to obtain a permit. The permit should not be granted until the owners of underground structures in the area have been consulted.

(d) Prohibit the encasement of pipes containing flammable materials within the constructed walls of new structures. This recommendation does not apply to piping entering buildings.

(e) Establish a procedure for connecting direct-current electrical equipment to ground on the premises of the user. This is to prevent the inclusion, directly or indirectly, of underground pipes carrying flammable materials in the return electric circuit.

(f) Promote cooperative efforts on the part of all organizations having underground facilities to reduce corrosion.

Chapter 4 Referenced Publications

4-1 The following documents or portions thereof are referenced within this recommended practice and should be considered part of the recommendations of this document. The edition indicated for each reference is the current edition as of the date of the NFPA issuance of this document.

4-1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 30, *Flammable and Combustible Liquids Code*, 1990 edition

NFPA 325M, *Fire Hazard Properties of Flammable Liquids, Gases, and Volatile Solids*, 1991 edition

NFPA 329, *Recommended Practice for Handling Underground Leakage of Flammable and Combustible Liquids*, 1992 edition

NFPA 495, *Explosive Materials Code*, 1992 edition.

4-1.2 API Publications. American Petroleum Institute, 1220 L St., NW, Washington, DC 20005.

API Recommended Practice 1621, *Bulk Liquid Stock Control at Retail Outlets*, Fourth Edition, 1987.

Appendix A

This Appendix is a not part of the recommendations of this NFPA document, but is included for information purposes only.

Properties of Some Flammable and Combustible Liquids and Gases That Have Been Found in Underground Structures¹

	Flash Point Closed Cup Deg. F	Flammable Limits in Air % by Vol		Specific Gravity of Liquid (Water = 1)	Vapor Density (Air = 1)
		Lower	Upper		
Acetone	-4	2.15	13.0	0.8	2.00
Acetylene	Gas	2.5	100.0	—	0.90
Ammonia	Gas	16.0	25.0	—	0.6
Benzene	12	1.3	7.1	0.9	2.8
Butadiene	Gas	2.0	12.0	—	1.9
Butane	Gas	1.6	8.5	—	2.00
Carbon Disulfide	-22	1.3	50.0	1.30	2.60
Carbon Monoxide	Gas	12.5	74.0	—	1.0
Ethane	Gas	3.0	12.5	—	1.0
Ethyl Chloride	-58	3.8	15.1	0.9	2.2
Gas Oil*	150*	0.5	5.0	< 1	—
Gasoline	-45	1.4	7.6	0.8	3.-4.0
(Values vary for different grades of gasoline)					
Hydrogen	Gas	4.0	75.0	—	0.1
Hydrogen Sulfide	Gas	4.0	44.0	—	1.2
Kerosene	100-162	0.7	5.0	< 1	—
Methane	Gas	5.0	15.0	—	0.6
Methyl Bromide	Gas	10.0	15.0	—	3.3
(Practically nonflammable)					
Methyl Chloride	Gas	8.1	17.4	—	1.8
Natural Gas*	Gas	3.8	13.0	—	—
Petroleum	< 0	1.1	5.9	0.6	2.5
Naphtha* (Petroleum Ether)					
Propane	Gas	2.1	9.5	—	1.6
Toluene	40	1.2	7.1	0.9	3.1

*These liquids and gases are mixtures, and their properties may vary depending on the composition.

¹Properties of other flammable materials can be found in NFPA 325M, *Fire Hazard Properties of Flammable Liquids, Gases, and Volatile Solids*.

Index

© 1992 National Fire Protection Association, All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document which it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of the National Fire Protection Association, Inc.

-C-

Carbon monoxide 2-4.2
Chemicals, accidental spillage 1-3.6
Contractors 3-13 thru 3-15
Corrosion, damage to underground lines 1-4.1
Currents, stray electric, damage to underground lines 1-4.2

-D-

Detection instruments 2-4
Drainage system, volatile flammable liquids in 2-5
Drains
 Automatic or manually operated in industrial piping 3-4
 Design of 3-8, 3-9
 Flushing and cleaning 2-7

-E-

Electric arc, heat of 1-2.4
Electric systems, underground 2-8
Excavating, damage to underground lines 1-4.4
Explosive hazard 3-1, 3-11

-F-

Fire chief, liaison with industrial safety officials 3-12
Fire, damage to underground lines 1-4.5
Flames, open 1-2.1, 1-2.3
Flammable and combustible gases see Gases, Flammable and combustible
Flammable and combustible liquids see Liquids, Flammable and combustible
Flammable limits 1-2.2, App. A
Flash point App. A

-G-

Gas services and mains, inactive 3-3
Gases
 Electric cable and other insulating material 1-3.5
 Flammable and combustible
 Properties of App. A
 Sources of 1-3
 Fuel 1-3.3, 2-4.4
 Natural 1-3.2
 Odorized gases 2-4.6
 Penetration of structures by 1-3.10
 Refrigerant 1-3.4
 Sewage 1-3.7

-H-

Hydrogen sulfide 2-4.3

-I-

Ignition, sources of 1-2, 2-2
Inspections 3-2, 3-5

-L-

Leaks, detection of 3-2
Liquids
 Flammable and combustible 1-3.8
 Pipelines for 3-5
 Properties of App. A
 Sources of 1-3
 Underground tanks 2-6
 Vapors from 2-4.4
 Volatile flammable 2-5
 Petroleum pipeline liquids 1-3.9

-O-

Open flames 1-2.1, 1-2.3
Oxygen 2-4.1

-P-

Protective practices Chap. 2
Public authorities
 Programs established by 3-8
 Responsibilities of 3-15

-S-

Service stations 3-6
Sewers
 Design of 3-8, 3-9
 Flushing and cleaning 2-7
Specific gravity App. A
Static electricity 1-2.5
Structural failures, underground 1-4.3
Summary Chap. 3
Switches, electric circuit oil 1-3.11

-T-

Tanks, underground, flammable liquids 2-6
Training, employee 3-7
Transformers, oil-insulated 1-3.11

-U-

Underground lines, damage to 1-4
Unsafe practices 1-5
Utility companies, inspection by 3-2

-V-

Vapor density App. A
Vapors, flammable 2-3, 2-4.4
Ventilation, manholes and vaults 3-10

The NFPA Codes and Standards Development Process

Since 1896, one of the primary purposes of the NFPA has been to develop and update the standards covering all areas of fire safety.

Calls for Proposals

The code adoption process takes place twice each year and begins with a call for proposals from the public to amend existing codes and standards or to develop the content of new fire safety documents.

Report on Proposals

Upon receipt of public proposals, the technical committee members meet to review, consider, and act on the proposals. The public proposals – together with the committee action on each proposal and committee-generated proposals – are published in the NFPA's Report on Proposals (ROP). The ROP is then subject to public review and comment.

Report on Comments

These public comments are considered and acted upon by the appropriate technical committees. All public comments – together with the committee action on each comment – are published as the Committee's supplementary report in the NFPA's Report on Comments (ROC).

The committee's report and supplementary report are then presented for adoption and open debate at either of NFPA's semi-annual meetings held throughout the United States and Canada.

Association Action

The Association meeting may, subject to review and issuance by the NFPA Standards Council, (a) adopt a report as published, (b) adopt a report as amended, contingent upon subsequent approval by the committee, (c) return a report to committee for further study, and (d) return a portion of a report to committee.

Standards Council Action

The Standards Council will make a judgement on whether or not to issue an NFPA document based upon the entire record before the Council, including the vote taken at the Association meeting on the technical committee's report.

Voting Procedures

Voting at an NFPA Annual or Fall Meeting is restricted to members of record for 180 days prior to the opening of the first general session of the meeting, except that individuals who join the Association at an Annual or Fall Meeting are entitled to vote at the next Fall or Annual Meeting.

"Members" are defined by Article 3.2 of the Bylaws as individuals, firms, corporations, trade or professional associations, institutes, fire departments, fire brigades, and other public or private agencies desiring to advance the purposes of the Association. Each member shall have one vote in the affairs of the Association. Under Article 4.5 of the Bylaws, the vote of such a member shall be cast by that member individually or by an employee designated in writing by the member of record who has registered for the meeting. Such a designated person shall not be eligible to represent more than one voting privilege on each issue, nor cast more than one vote on each issue.

Any member who wishes to designate an employee to cast that member's vote at an Association meeting in place of that member must provide that employee with written authorization to represent the member at the meeting. The authorization must be on company letterhead signed by the member of record, with the membership number indicated, and the authorization must be recorded with the President of NFPA or his designee before the start of the opening general session of the Meeting. That employee, irrespective of his or her own personal membership status, shall be privileged to cast only one vote on each issue before the Association.

Sequence of Events Leading to Publication of an NFPA Committee Document

Call goes out for proposals to amend existing document or for recommendations on new document.



Committee meets to act on proposals, to develop its own proposals, and to prepare its report.



Committee votes on proposals by letter ballot. If two-thirds approve, report goes forward. Lacking two-thirds approval, report returns to committee.



Report — *Report on Proposals* (ROP) — is published for public review and comment.



Committee meets to act on each public comment received.



Committee votes on comments by letter ballot. If two-thirds approve, supplementary report goes forward.
Lacking two-thirds approval, supplementary report returns to committee.



Supplementary report — *Report on Comments* (ROC) — is published for public review.



NFPA membership meets (Annual or Fall Meeting) and acts on committee report (ROP or ROC).



Committee votes on any amendments to report approved at NFPA Annual or Fall Meeting.



Appeals to Standards Council on Association action must be filed within 20 days of the NFPA Annual or Fall Meeting.



Standards Council decides, based on all evidence, whether or not to issue standard or to take other action, including upholding any appeals.

Committee Membership Classifications

The following classifications apply to Technical Committee members and represent their principal interest in the activity of a committee.

M *Manufacturer:* A representative of a maker or marketer of a product, assembly, or system, or portion thereof, that is affected by the standard.

U *User:* A representative of an entity that is subject to the provisions of the standard or that voluntarily uses the standard.

I/M *Installer/Maintainer:* A representative of an entity that is in the business of installing or maintaining a product, assembly, or system affected by the standard.

L *Labor:* A labor representative or employee concerned with safety in the workplace.

R/T *Applied Research/Testing Laboratory:* A representative of an independent testing laboratory or independent applied research organization that promulgates and/or enforces standards.

E *Enforcing Authority:* A representative of an agency or an organization that promulgates and/or enforces standards.

I *Insurance:* A representative of an insurance company, broker, agent, bureau, or inspection agency.

C *Consumer:* A person who is, or represents, the ultimate purchaser of a product, system, or service affected by the standard, but who is not included in the *User* classification.

SE *Special Expert:* A person not representing any of the previous classifications, but who has special expertise in the scope of the standard or portion thereof.

NOTE 1: "Standard" connotes code, standard, recommended practice, or guide.

NOTE 2: A representative includes an employee.

NOTE 3: While these classifications will be used by the Standards Council to achieve a balance for Technical Committees, the Standards Council may determine that new classifications of members or unique interests need representation in order to foster the best possible committee deliberations on any project. In this connection, the Standards Council may make such appointments as it deems appropriate in the public interest, such as the classification of "Utilities" in the National Electrical Code Committee.

NOTE 4: Representatives of subsidiaries of any group are generally considered to have the same classification as the parent organization.

FORM FOR PROPOSALS ON NFPA TECHNICAL COMMITTEE DOCUMENTS

Mail to: Secretary, Standards Council

National Fire Protection Association, 1 Batterymarch Park, Quincy, Massachusetts 02269-9101

Fax No. 617-770-3500

Note: All proposals must be received by 5:00 p.m. EST/EDST on the published proposal-closing date.

If you need further information on the standards-making process, please contact the
Standards Administration Department at 617-984-7249.
For technical assistance, please call NFPA at 617-770-3000

Please indicate in which format you wish to receive your ROP/ROC: ☐ electronic or ☐ paper

Date 9/18/93 Name John B. Smith Tel. No. 617-555-1212

Company _____

Street Address 9 Seattle St., Seattle, WA 02255

Please Indicate Organization Represented (if any) Fire Marshals Assn. of North America

1. a) NFPA Document Title National Fire Alarm Code NFPA No. & Year NFPA 72, 1993 ed.

b) Section/Paragraph 1-5.8.1 (Exception No.1)

2. Proposal recommends: (Check one) ☐ new text
☐ revised text
☒ deleted text

FOR OFFICE USE ONLY

Log # _____

Date Rec'd _____

3. Proposal (include proposed new or revised wording, or identification of wording to be deleted): (Note: Proposed text should be in legislative format: i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).

Delete exception.

4. Statement of Problem and Substantiation for Proposal: (Note: State the problem that will be resolved by your recommendation; give the specific reason for your proposal including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

A properly installed and maintained system should be free of ground faults. The occurrence of one or more ground faults should be required to cause a "trouble" signal because it indicates a condition that could contribute to future malfunction of the system. Ground fault protection has been widely available on these systems for years and its cost is negligible. Requiring it on all systems will promote better installations, maintenance and reliability.


5. ☒ This Proposal is original material. (Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought, or research and, to the best of his/her knowledge, is not copied from another source.)

☐ This Proposal is not original material; its source (if known) is as follows: _____

Note 1: Type or print legibly in black ink.

Note 2: If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.

I hereby grant NFPA the non-exclusive, royalty-free rights, including non-exclusive, royalty-free rights in copy-right, in this proposal and I understand that I acquire no rights in any publication of NFPA in which this proposal in this or another similar or analogous form is used.



Signature (Required)

PLEASE USE SEPARATE FORM FOR EACH PROPOSAL

FORM FOR PROPOSALS ON NFPA TECHNICAL COMMITTEE DOCUMENTS

Mail to: Secretary, Standards Council

National Fire Protection Association, 1 Batterymarch Park, Quincy, Massachusetts 02269-9101

Fax No. 617-770-3500

Note: All proposals must be received by 5:00 p.m. EST/EDST on the published proposal-closing date.

If you need further information on the standards-making process, please contact the
Standards Administration Department at 617-984-7249.
For technical assistance, please call NFPA at 617-770-3000

Please indicate in which format you wish to receive your ROP/ROC: ☐ electronic or ☐ paper

Date _____ Name _____ Tel. No. _____

Company _____

Street Address _____

Please Indicate Organization Represented (if any) _____

1. a) NFPA Document Title _____ NFPA No. & Year _____

b) Section/Paragraph _____

2. Proposal Recommends: (Check one) ☐ new text
☐ revised text
☐ deleted text

FOR OFFICE USE ONLY

Log # _____

Date Rec'd _____

3. Proposal (include proposed new or revised wording, or identification of wording to be deleted): (Note: Proposed text should be in legislative format: i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).

4. Statement of Problem and Substantiation for Proposal: (Note: State the problem that will be resolved by your recommendation; give the specific reason for your proposal including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

5. ☐ This Proposal is original material. (Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought, or research and, to the best of his/her knowledge, is not copied from another source.)

☐ This Proposal is not original material; its source (if known) is as follows: _____

Note 1: Type or print legibly in black ink.

Note 2: If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.

I hereby grant NFPA the non-exclusive, royalty-free rights, including non-exclusive, royalty-free rights in copyright, in this proposal and I understand that I acquire no rights in any publication of NFPA in which this proposal in this or another similar or analogous form is used.

Signature (Required)

PLEASE USE SEPARATE FORM FOR EACH PROPOSAL

Cut here

Bibliography of NFPA Standards

- 1 Fire Prevention Code
- 10 Portable Extinguishers
- 10R Portable Fire Extinguishing Equipment in Dwellings
- 11 Low-Expansion Foam
- 11A Medium- and High-Expansion Foam Systems
- 11C Mobile Foam Apparatus
- 12 Carbon Dioxide Systems
- 12A Halon 1301 Systems
- 13 Sprinkler Systems
- 13D Sprinkler Sys., Dwellings
- 13E Sprinkler Prop., F.D. Operations in
- 13R Sprinkler Sys., Res. Occ. up to and Including 4 Stories
- 14 Standpipe, Hose Systems
- 15 Water Spray Fixed Systems
- 16 Deluge Foam-Water Systems
- 16A Closed Head Foam-Water Sprinkler Systems
- 17 Dry Chem. Ext. Systems
- 17A Wet Chem. Ext. Systems
- 18 Wetting Agents
- 20 Centrifugal Fire Pumps
- 22 Water Tanks
- 24 Private Fire Service Mains
- 25 Water-Based Fire Prot. Systems
- 30 Flam. Liquids Code
- 30A Automotive and Marine Service Station Code
- 30B Aerosol Products
- 31 Oil-Burning Equipment
- 32 Drycleaning Plants
- 33 Spray Application
- 34 Dipping and Coating Processes
- 35 Organic Coatings
- 36 Solvent Extraction Plants
- 37 Combustion Engines and Gas Turbines
- 40 Motion Picture Film
- 42 Pyroxylin Plastic
- 43D Pesticides, Storage
- 45 Laboratories Using Chemicals
- 46 Forest Products, Storage
- 49 Hazardous Chemicals Data
- 50 Bulk Oxygen Systems
- 50A Gaseous Hydrogen Systems
- 50B Liquefied Hydrogen Systems
- 51 Welding, Cutting and Allied Processes
- 51A Acetylene Charging Plants
- 51B Cutting and Welding Processes
- 52 CNG Vehicular Fuel Systems
- 53 Oxy. Atmospheres, Fires in
- 54 Nat'l Fuel Gas Code
- 55 Compressed and Liquefied Gases in Portable Cylinders
- 57 LNG Vehicular Fuel Systems
- 58 LP-Gas Storage
- 59 LP-Gas, Utility Plants
- 59A LN-Gas, Stg., Handling
- 61 Agricultural and Food Products Facilities
- 65 Aluminum Processing
- 68 Venting of Deflagrations
- 69 Explosion Prev. Systems
- 70 *National Electrical Code*
- 70B Elect. Equip. Maint.
- 70E Electrical Safety in Employee Work
- 72 National Fire Alarm Code
- 73 Residential Elect. Maint. for Dwellings
- 75 Electronic Computer Systems
- 77 Static Electricity
- 79 Elect. Std. for Ind. Machinery
- 80 Fire Doors and Fire Windows
- 80A Exterior Fire Exposure, Prot. from
- 82 Incinerators, Systems & Equip.
- 86 Ovens and Furnaces
- 86C Ind. Furn., Sp. Processing
- 86D Ind. Furnaces, Vacuum
- 88A Parking Structures
- 88B Repair Garages
- 90A Air Conditioning Systems
- 90B Warm Air Htg., Air Cond.
- 91 Exhaust Syst. for Air Conveying of Materials
- 92A Smoke-Mgmt. Syst. in Malls, Atria, Large Areas
- 96 Commercial Cooking Operations
- 97 Heating Terms, Glossary
- 99 Health Care Facilities
- 99B Hypobaric Facilities
- 101' *Life Safety Code*
- 101A Alt. Approaches to Life Safety
- 102 Grandstands, Folding/Telescopic Seating, Tents, and Membrane Struct.
- 105 Smoke-Control Door Assemblies
- 110 Emer., Standby Power Systems
- 111 Stored Electrical Energy Emer. & Standby Power Systems
- 115 Laser Fire Protection
- 120 Coal Preparation Plants
- 121 Self-Propelled & Mobile Surface Mining Equip.
- 122 Underground Metal and Nonmetal Mines
- 123 Undergr. Bituminous Coal Mines
- 130 Fixed Guideway Transit Syst.
- 150 Racetrack Stables
- 170 Fire Safety Symbols
- 203 Roof Coverings/Roof Deck
- 204M Smoke, Heat Venting
- 211 Chimneys, Fireplaces, Vents
- 214 Water Cooling Towers
- 220 Types Bldg. Construction
- 231 General Storage
- 231C Rack Storage of Mat'ls.
- 231D Rubber Tires, Storage
- 231E Baled Cotton, Storage
- 231F Roll Paper, Storage
- 232 Records, Prot.
- 232A Archives and Records Centers
- 241 Construction, Alteration, and Demolition Operations
- 251 Bldg Constr. & Mat'ls., Fire Tests
- 252 Door Assem., Fire Tests of
- 253 Floor Covering Systems, Test for
- 255 Bldg. Mat'ls., Burning Character
- 256 Roof Coverings, Tests of
- 257 Window Assemblies, Tests of
- 258 Smoke Generation, Test of
- 259 Heat of Bldg. Mat'ls., Test for
- 260 Cig. Ignition Resistance—Components of Furniture, Tests for
- 261 Cig. Ignition Resistance—Uphol. Furn. Assem., Tests for
- 262 Wires and Cables, Test for Fire and Smoke Char. of
- 263 Heat & Smoke Release Rates, Test for
- 264 Heat-Release Rates Using Oxygen-Consumption Calorimeter, Test for
- 264A Heat Release Rates—Uphol. Furn. Comp. & Mattresses
- 265 Textile Wall Coverings—Room Fire Growth Contribution, Tests for
- 266 Uphol. Furn. Exp. to Flaming Ignition Sources, Test for
- 267 Mattress and Bedding Exp. to Flaming Ignition Source, Test for
- 268 Ignitibility of Exterior Wall Assemblies, Test for
- 269 Toxic Potency Data for Fire Hazard Modeling, Test for
- 291 Fire Hydrants
- 295 Wildfire Control
- 297 Communications Systems
- 298 Foam Chem. for Class A Fuels/Rural Suburban
- 299 Wildfire, Protection Life and Property from
- 302 Pleasure and Comm. Motor Craft
- 303 Marinas and Boatyards
- 306 Vessels, Gas Hazards on
- 307 Marine Terminals, Piers, Wharves
- 312 Vessels, Constr., Repair
- 318 Cleanrooms
- 325 Prop. of Flam. Liquids, Gases, Solids
- 326 Underground Storage Tanks, Safe Entry
- 327 Cleaning Small Tanks
- 328 Manholes, Sewers, Flam. Liquids and Gases in
- 329 Flam. and Com. Liquid, Underground Releases
- 385 Tank Vehicles
- 386 Portable Shipping Tanks
- 395 Farms, Storage Flam. Liquids
- 402 Aircraft Rescue, Fire Fighting
- 403 Aircraft Rescue Services
- 407 Aircraft Fuel Servicing
- 408 Aircraft Extinguishers
- 409 Aircraft Hangars
- 410 Aircraft Maintenance
- 412 Eval., Foam Equip. for Aircraft
- 414 Aircraft Rescue Vehicles
- 415 Aircraft/Terminal Buildings, Fueling Ramp Drainage, Loading Walkways
- 418 Heliports
- 422 Aircraft Accident Response
- 423 Aircraft Engine Test Facilities
- 424 Airport/Community Emerg. Planning
- 430 Liquid/Solid Oxidizers
- 432 Organic Peroxide Formulations
- 471 Responding to Haz. Mat. Incidents
- 472 Haz. Mat. Resp. Prof. Comp.
- 473 Competencies for EMS Personnel
- 480 Magnesium
- 481 Titanium
- 482 Zirconium
- 485 Lithium Metal
- 490 Ammonium Nitrate
- 491 Haz. Chem. Reactions
- 495 Explosive Materials
- 496 Purged Enclosures, Elec. Equip.
- 497 Flam. Liq., Gases, or Vapors and of Haz. Locations for Elec. Inst.
- 498 Explosives Motor Vehicle Term.
- 499 Comb. Dusts and of Haz. Locations for Elec. Inst. in Chem. Process Areas
- 501 Manufactured Housing
- 501A Manufactured Home Instal., Sites
- 501C Recreational Vehicles
- 501D Recreational Vehicle Parks
- 502 Highways, Tunnels, Bridges
- 505 Powered Industrial Trucks
- 512 Truck Fire Protection
- 513 Motor Freight Terminals
- 550 Fire Safety Concepts Tree
- 555 Evaluating Potential for Room Flashover
- 560 Ethylene Oxide
- 600 Industrial Fire Brigades
- 601 Guard Service
- 650 Pneumatic Conveying Systems
- 651 Aluminum Powder
- 654 Manufacturing, Processing, and Handling of Combust. Particulate Solids
- 655 Sulfur Fires and Explosions
- 664 Wood Processing, Woodworking
- 701 Textiles, Films, Fire Tests
- 703 Fire-Ret. Treat. of Bldg. Mat'ls.
- 704 Fire Hazards of Materials
- 705 Field Flame Test for Textiles and Films
- 750 Water Mist Fire Protection Systems
- 780 Lightning Protection Systems
- 801 Radioactive Materials Facilities
- 802 Nuclear Research Reactors
- 803 Light Water Nuclear Power Plants
- 804 Adv. Light Water Reactor Electric Generating Plants
- 820 Wastewater Facilities
- 850 Electric Generating Plants
- 851 Hydroelectric Generating Plants
- 901 Incident Reporting, Fire Prot. Data
- 902 Field Incident Manual
- 903 Property Survey Guide
- 904 Incident Follow-up Report Guide
- 906 Fire Incident Field Notes
- 909 Cultural Resources
- 914 Fire Prot. in Historic Struc.
- 921 Fire and Explosion Investigations
- 1000 Prof. Qual. Accreditation and Cert. Sys.
- 1001 Fire Fighter Prof. Qual.
- 1002 F.D. Vehicle Driver Prof. Qual.
- 1003 Airport Fire Fighter Prof. Qual.
- 1021 Fire Officer Prof. Qual.
- 1031 Fire Inspector Prof. Qual.
- 1033 Fire Investigator Prof. Qual.
- 1035 Public Fire Educator Prof. Qual.
- 1041 Fire Instructor Prof. Qual.
- 1051 Wildland Fire Fighter Prof. Qual.
- 1061 Public Safety Telecommunicator Prof. Qual.
- 1122 Model Rocketry
- 1123 Fireworks Display
- 1124 Fireworks, Mfg., Trans., Stge
- 1125 Model Rocket/High Power Rocket Motors, Mfg.
- 1126 Pyrotechnics Before Proximate Audience
- 1127 High Power Rocketry
- 1141 Planned Building Groups
- 1201 Devel. of FP Services for Public
- 1221 Public Fire Serv. Comm. Sys.
- 1231 Suburban & Rural Water Supplies
- 1401 Training Reports, Records
- 1402 Building Training Centers
- 1403 Live Fire Training Evolutions
- 1404 FD SCBA Program
- 1405 Land-Based Fire Fighters Who Respond to Marine Vessel Fires
- 1410 Initial Fire Attack
- 1420 Warehouse Occupancies
- 1451 Fire Service Vehicle Operations Training Prog.
- 1452 Dwelling Fire Safety Surveys
- 1470 Search and Rescue, Struct. Collapse
- 1500 Fire Dept. Occupational Safety and Health Prog.
- 1521 Fire Dept. Safety Officer
- 1561 F.D. Incident Management Syst.
- 1581 F.D. Infection Control Program
- 1582 Medical Requirements for Fire Fighters
- 1600 Disaster Management
- 1901 Automotive Fire Apparatus
- 1906 Wildland Fire Apparatus
- 1911 Fire Pump Systems on Fire Apparatus, Tests of
- 1914 F.D. Aerial Devices, Testing
- 1921 Portable Pumping Units
- 1922 Self-Contained Pumping Units
- 1931 Fire Dept. Ground Ladders, Design
- 1932 Fire Dept. Ground Ladders, Use
- 1961 Fire Hose
- 1962 Fire Hose Care, Use
- 1963 Fire Hose Connections
- 1964 Spray Nozzles (Shutoff and Tip)
- 1971 Prot. Ensemble, Structural Fire Fighting
- 1975 Station/Work Uniforms for FF
- 1976 Prot. Clothing - Proximity Fire Fighting
- 1977 Prot. Clothing - Wildland Fire Fighting
- 1981 Open-Circuit Self-Contained Breathing App. for Fire Service
- 1982 Personal Alert Safety Systems for Fire Fighters
- 1983 Life Safety Rope and Sys. Comp.
- 1991 Vapor-Protective Suits for Haz. Chem. Emergencies
- 1992 Liquid Splash-Protective Suits for Haz. Chem. Emergencies
- 1993 Support Function Prot. Clothing for Haz. Chem. Oper.
- 1999 Prot. Clothing - Medical Emerg. Oper.
- 2001 Clean Agent Ext. Systems
- 8501 Single Burner Boiler Operation
- 8502 Furnace Explosions/Implosions in Multiple Boilers
- 8503 Pulverized Fuel Systems
- 8504 Atmospheric Fluidized-Bed Boiler Operation
- 8505 Stoker Operation
- 8506 Heat Recovery Steam Generators



National Fire Protection Association

1 Batterymarch Park, PO Box 9101, Quincy, MA 02269-9101
To Order Products, Call Toll-Free: 1-800-344-3555